

Certificate

Hygiene conformity test according to standard ISO846:1997 (F)

CONIDIA is an independent laboratory specialist of the study of microorganisms and more particularly the relationship between moulds and materials.

Tests on **Air filter from AAF** were performed in 2017 to test their hygiene conformity. Tests were performed following the standard ISO846:1997 between the 24.03.17 and the 21.04.17 at CONIDIA laboratory (69650 Quincieux, FRANCE).

Tested type serie:

- AstroCel

Manufacturer : AAF -International.

The standard ISO846:1997 is following the requirements of European hygienic guidelines for standard climatisation (e.g. **VDI 6022**) and hospitals (e.g. **DIN1946**).

Data of this test are compiled in the report N° 0816-004_1 edited by CONIDIA laboratory the 28.04.2017.

Quincieux, 01.06.2017

VACHER Sébastien
PhD of microbiology
CONIDIA manager

 **CONIDIA**
Parc d'activités en Chuel - Bât 2
69650 Quincieux, France
Tel. (+33)4 69 64 72 85
Fax (+33)4 69 64 72 86