

# Suoritustasoilmoitus

**Numero:** Suoritustasoilmoitus\_F-R60K\_B\_EN

## 1. Unique Identification Code of the Product

F-R60K

## 2. Type

Systemair Fire Damper F-R60K

## 3. Intended Use of the Construction Product

Fire closure for HVAC ductworks for the compartmentization

## 4. Name, Registered Trade Name and Contact Address of the Manufacturer

Systemair Production a.s.

Hlavná 371,

90043 Kalinkovo, Slovakia

## 5. Where Applicable, Name and Contact Address of the Authorized Representative

---

## 6. System of Assessment and Verification of Constancy of Performance of the Construction Product

System 1

## 7. Harmonized Product Standard, Test Standard, Classification Standard

EN 15 650:2010

## 8. Identification Number of the Notified Body

1396

Name and address of the notified person:

**FIRES s.r.o.,**

Osloboditeľov 282,

059 35 Batizovce, Slovakia












Notified person performed in system 1 the determination of the product type based on type testing (including sampling) and descriptive documentation of the production initial inspection of the manufacturing plant and of factory production control and continuous surveillance, assessment and evaluation of factory production control and issued certificate of constancy of performance:



1396 - CPR - 0194

## 9. Ilmoitetut suoritusastot:

Asennukset:

 <p>ON</p>	<p>F-R60K DN100 ... DN630</p>	<p>EI 60 (v<sub>e</sub> - i ↔ o) S</p>	<p>a)  b) </p> <p>≥ 100 mm      ≥ 100 mm</p>	 <p>360°</p>
		<p>EI 60 (h<sub>o</sub> - i ↔ o) S</p>	<p>d)  e) </p> <p>≥ 80 mm      ≥ 100 mm</p>	
 <p>OUT</p>	<p>F-R60K DN100 ... DN630</p>	<p>EI 60 (v<sub>e</sub> - i ↔ o) S</p>	<p>a)  b) </p> <p>≥ 100 mm      ≥ 100 mm</p>	 <p>360°</p>
		<p>EI 60 (h<sub>o</sub> - i ↔ o) S</p>	<p>c) </p> <p>≥ 100 mm ≥ 620 kg/m<sup>3</sup></p>	

**Legend:**

**On** - Damper installed on a supporting construction

**Out** - Damper installed remotely from the supporting construction

**a)** - Flexible (plasterboard) wall

**b)** - Concrete/masonry/cellular concrete (rigid) wall

**c)** - Concrete/cellular concrete (rigid) floor/ceiling

**d)** - Shaft wall - one side covered with 2 layers of gypsum board

**v<sub>e</sub>** - Vertical wall

**h<sub>o</sub>** - Horizontal floor/ceiling

Ominaisuus	Testiasetus	Luokittelustandardi	Arvioinnin tekninen eritelmä	Suorituskyky ilmaistuna	Arviointi
Nominal activation /Sensing element conditions /sensitivity	ISO 10294-4	/	EN 15650 4.2.1.2 4.2.1.2.2 4.2.1.2.3	• kantavuus ISO 10294-4, 4.2 mukaisesti; • vastelämpötila ISO 10294-4, 4.2 mukaisesti;	<b>Hyväksytty</b>
Vasteviive (vasteaika)	EN 1366-2	/	EN 15650 4.2.1.3	• sulkemisaika kahden minuutin kuluessa	<b>Hyväksytty</b>
Toimintavarmuus	EN 1366-2 cl. 10.2	/	EN 15650 4.3.1 a)	50 sykliä	<b>Hyväksytty</b>
Palonkestävyys • eheys • eristys • savunvuoto • mekaaninen vakaus	EN 1366-2	EN 13501-3 + A1	EN 15650, cl. 4.1.1, a), cl. 4.1.1 b), cl. 4.1.1 c), cl. 4.1.1 a),	Katso asennustaulukko 9.	<b>Hyväksytty</b>
Palonkestävyys • poikkileikkausten ylläpito	EN 1366-2	EN 13501-3 + A1	EN 15650, cl. 4.4.1 a)	Katso asennustaulukko 9.	<b>Hyväksytty</b>
Vasteajan kestävyys	ISO 10294-4	/	EN 15650 4.3.3.1	Savunhallintapelti sulkeutuu määrättyyn aikaan ja vaadittuna ajanjaksona.	<b>Hyväksytty</b>
Toiminnallisen luotettavuuden kestävyys	EN 15650 Liite C	/	EN 15650 4.3.3.2	10 000 sykliä alueella 0° - 90° jonkä jälkeen 10 000 sykliä välillä puoliavoin - kaksi kolmasosaa auki.	<b>Hyväksytty</b>

Tämä suoritustasoilmoitus on annettu kohdassa 4 ilmoitetun valmistajan yksinomaisella vastuulla. Valmistajan puolesta allekirjoittanut:



Kalinkovo, Syyskuu 30, 2024

Ing. Maroš Chlebo, Managing Director

{DoP\_Note\_3}

# Declaration of Performance

Number: DeclarationOfPerformance\_F-R60K\_B\_EN

## 1. Unique Identification Code of the Product

F-R60K

## 2. Type

Systemair Fire Damper F-R60K

## 3. Intended Use of the Construction Product

Fire closure for HVAC ductworks for the compartmentization

## 4. Name, Registered Trade Name and Contact Address of the Manufacturer

Systemair Production a.s.

Hlavná 371,  
90043 Kalinkovo, Slovakia

## 5. Where Applicable, Name and Contact Address of the Authorized Representative

---

## 6. System of Assessment and Verification of Constancy of Performance of the Construction Product

System 1

## 7. Harmonized Product Standard, Test Standard, Classification Standard

EN 15 650:2010

## 8. Identification Number of the Notified Body

1396

Name and address of the notified person:

FIRES s.r.o.,  
Osloboditeľov 282,











059 35 Batizovce, Slovakia

Notified person performed in system 1 the determination of the product type based on type testing (including sampling) and descriptive documentation of the production initial inspection of the manufacturing plant and of factory production control and continuous surveillance, assessment and evaluation of factory production control and issued certificate of constancy of performance:



## 9. Declared Performance:

Installations:

 ON	F-R60K DN100 ... DN630	El 60 (v <sub>e</sub> - i ↔ o) S	a)  b)  ≥ 100 mm      ≥ 100 mm	 360°
		El 60 (h <sub>o</sub> - i ↔ o) S	d)  ≥ 80 mm	
 OUT	F-R60K DN100 ... DN630	El 60 (v <sub>e</sub> - i ↔ o) S	a)  b)  ≥ 100 mm      ≥ 100 mm	 360°
		El 60 (h <sub>o</sub> - i ↔ o) S	d)  ≥ 80 mm	

**Legend:**

**On** - Damper installed on a supporting construction

**Out** - Damper installed remotely from the supporting construction

**a)** - Flexible (plasterboard) wall

**b)** - Concrete/masonry/cellular concrete (rigid) wall

**c)** - Concrete/cellular concrete (rigid) floor/ceiling

**d)** - Shaft wall - one side covered with 2 layers of gypsum board

**e)** - Sandwich wall - non-loadbearing wall, double sided steel horizontal panel, with mineral wool core

**v<sub>e</sub>** - Vertical wall

**h<sub>o</sub>** - Horizontal floor/ceiling

ENGLISH ORIGINAL  
DECLARATION  
OF PERFORMANCE



Property	Test regulation	Classification standard	Technical specification for assessment	Performance expressed	Evaluation
Nominal activation /Sensing element conditions /sensitivity	ISO 10294-4	/	EN 15650 4.2.1.2 4.2.1.2.2 4.2.1.2.3	<ul style="list-style-type: none"> <li>load-bearing capacity</li> </ul> in accordance with ISO 10294-4, 4.2; <ul style="list-style-type: none"> <li>response temperature</li> </ul> in accordance with ISO 10294-4, 4.2;	<b>Satisfied</b>
Response delay (response time)	EN 1366-2	/	EN 15650 4.2.1.3	<ul style="list-style-type: none"> <li>closure time</li> </ul> within time period of 2 minutes	<b>Satisfied</b>
Operational reliability	EN 1366-2 cl. 10.2	/	EN 15650 4.3.1 a)	50 cycles	<b>Satisfied</b>
Fire resistance <ul style="list-style-type: none"> <li>integrity</li> <li>insulation</li> <li>smoke leakage</li> <li>mechanical stability</li> </ul>	EN 1366-2	EN 13501-3 + A1	EN 15650, cl. 4.1.1, a), cl. 4.1.1 b), cl. 4.1.1 c), cl. 4.1.1 a),	See installation Table 9.	<b>Satisfied</b>
Fire resistance <ul style="list-style-type: none"> <li>maintenance of cross-section</li> </ul>	EN 1366-2	EN 13501-3 + A1	EN 15650, cl. 4.4.1 a)	See installation Table 9.	<b>Satisfied</b>
Durability of response delay	ISO 10294-4	/	EN 15650 4.3.3.1	Durability of response delay (by tested temperature response and load-bearing capacity) is preserved.	<b>Satisfied</b>
Durability of operational reliability	EN 15650 Annex C	/	EN 15650 4.3.3.2	10 000 cycles at the range from 0° to 90° followed by 10 000 cycles at range from half open to two thirds open.	<b>Satisfied</b>

This declaration of performance is issued under the sole responsibility of the manufacturer identified in point 4. Signed for and on behalf of the manufacturer by:



Kalinkovo, September 30, 2024

Ing. Maroš Chlebo, Managing Director

ENGLISH ORIGINAL  
DECLARATION  
OF PERFORMANCE