


# S-SA1

## Smoke Control Damper - AAsingle

Handbook



# Table of Contents

Overview . . . . .3

Technical Parameters . . . . .6

Diagrams . . . . .8

Dimensions & Weights . . . . .17

Ordering Code . . . . .21

Product Handling . . . . .22

Installation . . . . .26

Electrical Parameters . . . . .32

Operation Manual . . . . .44



## Description

S-SA1 smoke control dampers operate with mechanical or natural smoke and heat extraction systems. They remove poisonous gases, smoke and fire and can also supply clean air to fire compartments.

S-SA1 dampers have an actuator without a spring. Thus, they have two safety positions: an “open” position and a “closed” position. Power is necessary for the smoke control dampers.

S-SA1 dampers are designed for on a duct installations ended with grille, not in the wall or ceiling. The “Installation Methods” section shows the types of installations that are permitted.

### Special Properties

- The pressure level is 3 (-1500 Pa ... 500 Pa)
- The blade leakage class 3 (compliant with EN 1751)
- The casing leakage class C (compliant with EN 1751)
- AA – automatic activation (sets the safety position within 60 seconds). No thermal insulation around the actuator needed.

### Fire Resistivity

S-SA1 smoke control dampers have a CE certification that meets the EU’s Construction Products Regulation and complies with Standard EN 12101-8:2011, EN 1366-10:2022, and EN 1366-2:2015 are the reference Standards for the tests. EN 13501-4:2016 is the reference Standard for the Classification.

Resistivity rating for damper installed on the duct: **E<sub>600</sub> 120 (v<sub>ed</sub> - i↔o) S1500 C<sub>mod</sub> AAsingle**

### Types of Activation

- **B230** - Activation mechanism with a Belimo actuator (230V AC) and auxiliary switches
- **B24** - Activation mechanism with a Belimo actuator (24V AC/DC) and auxiliary switches
- **B24-W** - Activation mechanism with a Belimo actuator (24V AC/DC) and auxiliary switches, with provided cable connectors for the supply and communication unit (communication unit not part of the mechanism)
- **B24-SR** - Activation mechanism with a modulating Belimo actuator (24V AC/DC; 0(2) V...10 V DC) and auxiliary switches. Modulating actuators have the possibility to open the blade at a desired angle.
- **BST0** - Activation mechanism with a Belimo actuator (AC/DC 24 V) with a supply and communication unit (AC 230 V) BKNE230-24 (2-wire to BKSE...)
- **BST1** - Activation mechanism with a Belimo actuator (AC/DC 24 V) with a supply and communication unit (SLC powered) BC24-G2 (THC)
- **BST10** - Activation mechanism with a Belimo actuator (AC/DC 24 V) with a supply and communication unit (AC 230 V) BKNE230-24-PL (Powerline)

### Accessories

Detailed information about accessories is available in [design.systemair.com](https://design.systemair.com)

- GE1-S-SA1: Extension with Grille for S-SA1

## Design

The casing of the S-SA1 is made of a galvanized sheet metal. Blades are made from calcium silicate boards with a silicone rubber gasket which prevent leaks of heat or smoke. The casing has flange on two sides with holes for screws to attach to sheet-metal duct flanges. The damper casing has inspection openings. The mechanisms actuator of the S-SA1 is accesible from the outside.


### Composition of Materials

The product contains these materials:

- Galvanized sheet metal
- Calcium silicate board
- Ethylene-propylene rubber
- Galvanized steel fasteners

The manufacturing processes of these materials agree with local regulations. The product does not contain dangerous materials. No silicone caulks are used in the manufacturing processes.

## Product Parts



## Legend

**P1** - Damper casing

**P2** - Damper blade

**P3** - Actuator

**P4** - Holder for actuator

**P5** - Supply and communication unit (only for BST0, BST1, BST10 activation type)

**P6** - Holder for communication unit (without unit installed only for B24-W activation type)

**P7** - Inspection lid

**P8** - Product label

**A1** - Extension with Grille (GE1-S-SA1) is not part of S-SA1 delivery

**A1.1** - Extended ductwork

**A1.2** - Grid

# Technical Parameters

## Durability Test

- Test procedure with 10000 cycles and actuator control (rotation from 0° to 90°)
- Test procedure with 10000 cycles and actuator control for "mod" classification (rotation from 45° to 60°)
- No change of the necessary properties.
- No change of the necessary properties.

## Tested Pressures

Maximum underpressure	1500 Pa
Maximum overpressure	500 Pa

**Safe Position** Open or closed

**Possible Installations** Refer to the "Installation" section

**Direction of the Airflow** Both direction for supply or extract

**Permitted air Velocity During Blade Movement** 12 m/s

**Side with Fire Protection** Both sides: (i<->o) - symmetrical

**Closing and Opening Time** Motor running time: <60 s / 90°

**Closed or Open Status Indicator** Microswitches that are part of the mechanism actuator signal the closed or open status.

## Environmental Conditions for Operation

The temperatures must be:	-20 °C ... 50 °C
Relative humidity:	Less than 95% (3K21, EN 60721-3-3)
Product protected from:	Weather, rain and water from other sources
Condensation:	Cannot form on the product
Icing:	Cannot form on the product

## Access for Inspection

The inspection is possible through the grille when available or through an inspection opening on the damper body. Connection and actuator accessible from outside.

<b>Maintenance</b>	Maintenance is not necessary. A dry-cleaning procedure can be mandatory in some countries or when needed.
--------------------	---

## Inspections

Obey local laws for the minimum time between inspection procedures. When not specified the maximum interval between inspections is 6 months

**Tightness of the Blade** Class 3 of Standard EN 1751 at 500 Pa

**Tightness of the Housing** Class C of Standard EN 1751 at 500 Pa

## EC Directives

2006/42/EC Machinery Directive  
2014/35/EU Low Voltage Directive  
2014/30/EU Electromagnetic Compatibility Directive

## Driving Actuator Types

Belimo BEN..., BEE..., BE... ...230; ...24; ...24-ST; ...24-SR

**Transportation and Storage** The temperature range must be: -30...50 °C

Make sure that the damper blade is in the closed position during transportation and protected from weather disruptions. The storage of the smoke control damper must be indoors.

# Assessed Performance

23 CE 1396

**Systemair Production a.s.**

Hlavná 371, 900 43 Kalinkovo, Slovakia

1396-CPR-0229

**S-SA1****EN 12101-8 : 2011**

Smoke control damper

**Nominal Activation Conditions/Sensitivity****Pass****Response Delay (Response Time)**

Opening/closure time proven. Duration: &lt;60 s / 90°

**Operational Reliability****C<sub>mod</sub>**: 20.000 cycles (modulated)**Fire resistance:****E<sub>600</sub> 120 (v<sub>ed</sub> - i ↔ o) S1500 C<sub>mod</sub> AA<sub>single</sub>**

Resistivity depends on installation method and situation

• integrity

**E**

maintenance of the cross section

(under E)

mechanical stability

(under E)

• smoke leakage

**S****Durability of Response Delay****AA** - Automatic Activation. Opening/closure time proven.  
Duration: <60 s / 90°**Durability of Operational Reliability****C<sub>mod</sub>**: 20.000 cycles. Cycle duration: <120 s


# Diagrams

The pressure drop, and A-weighted total discharged sound power level depend on the nominal width and height of the damper and air flow volume at different duct pressures. The type of activation does not influence the airflow parameter, therefore only one activation type is shown in the diagrams.

## Diagrams for Extract Air


S-SA1-...-B230

Pressure drop & A-weighted sound power level in dB(A)




S-SA1-...-B230

Pressure drop & A-weighted sound power level in dB(A)




S-SA1-...-B230

Pressure drop & A-weighted sound power level in dB(A)



S-SA1-...-B230


Pressure drop & A-weighted sound power level in dB(A)






S-SA1-...-B230

Pressure drop & A-weighted sound power level in dB(A)




S-SA1-...-B24-SR

Pressure drop & A-weighted sound power level in dB(A)




S-SA1-...-B24-SR

Pressure drop & A-weighted sound power level in dB(A)




S-SA1-...-B24-SR

Pressure drop & A-weighted sound power level in dB(A)




S-SA1-...-B24-SR

Pressure drop & A-weighted sound power level in dB(A)



S-SA1-...-B24-SR


Pressure drop & A-weighted sound power level in dB(A)



Diagrams for Supply Air


S-SA1-...-B230

Pressure drop & A-weighted sound power level in dB(A)




S-SA1-...-B230

Pressure drop & A-weighted sound power level in dB(A)




S-SA1-...-B230

Pressure drop & A-weighted sound power level in dB(A)




S-SA1-...-B230

Pressure drop & A-weighted sound power level in dB(A)




S-SA1-...-B230

Pressure drop & A-weighted sound power level in dB(A)




S-SA1-...-B24-SR

Pressure drop & A-weighted sound power level in dB(A)




S-SA1-...-B24-SR

Pressure drop & A-weighted sound power level in dB(A)




S-SA1-...-B24-SR

Pressure drop & A-weighted sound power level in dB(A)




S-SA1-...-B24-SR

Pressure drop & A-weighted sound power level in dB(A)



S-SA1-...-B24-SR


Pressure drop & A-weighted sound power level in dB(A)



Diagrams for Extract with GE1-S-SA1 Accessory


S-SA1-...-B230

Pressure drop & A-weighted sound power level in dB(A)




S-SA1-...-B230

Pressure drop & A-weighted sound power level in dB(A)




S-SA1-...-B230

Pressure drop & A-weighted sound power level in dB(A)




S-SA1-...-B230

Pressure drop & A-weighted sound power level in dB(A)




S-SA1-...-B230

Pressure drop & A-weighted sound power level in dB(A)




S-SA1-...-B24-SR

Pressure drop & A-weighted sound power level in dB(A)




S-SA1-...-B24-SR

Pressure drop & A-weighted sound power level in dB(A)




S-SA1-...-B24-SR

Pressure drop & A-weighted sound power level in dB(A)




S-SA1-...-B24-SR

Pressure drop & A-weighted sound power level in dB(A)



S-SA1-...-B24-SR


Pressure drop & A-weighted sound power level in dB(A)



Diagrams for Supply with GE1-S-SA1 Accessory


S-SA1-...-B230

Pressure drop & A-weighted sound power level in dB(A)




S-SA1-...-B230

Pressure drop & A-weighted sound power level in dB(A)




S-SA1-...-B230

Pressure drop & A-weighted sound power level in dB(A)




S-SA1-...-B230

Pressure drop & A-weighted sound power level in dB(A)




S-SA1-...-B230

Pressure drop & A-weighted sound power level in dB(A)




S-SA1-...-B24-SR

Pressure drop & A-weighted sound power level in dB(A)




S-SA1-...-B24-SR

Pressure drop & A-weighted sound power level in dB(A)




S-SA1-...-B24-SR

Pressure drop & A-weighted sound power level in dB(A)




S-SA1-...-B24-SR

Pressure drop & A-weighted sound power level in dB(A)



S-SA1-...-B24-SR

Pressure drop & A-weighted sound power level in dB(A)



Legend:


**Pa** - Pressure drop ( $p_s$ )

**m<sup>3</sup>/h; l/s** - Air flow volume ( $q_v$ )





# Dimensions & Weights

Dimensions of S-SA1



S-SA1		H (mm)									
		200	250	300	350	400	450	500	600	700	800
$R_1$	mm	4	29	54	79	104	129	154	204	254	304
$R_2$		-141	-116	-91	-66	-41	-16	9	59	109	159

Dimensions of GE1-S-SA1



NOTE: \*Accessory GE1-S-SA1 sold separately. GE1-S-SA1 is not part of the S-SA1 delivery.

GE1-S-SA1		H (mm)									
		200	250	300	350	400	450	500	600	700	800
R <sub>1</sub>	mm	4	29	54	79	104	129	154	204	254	304
L <sub>1</sub> <sup>*</sup>		-					100			200	
L <sub>2</sub> <sup>*</sup>		325					425			525	

**Free Area of S-SA1 Without Grille**

A <sub>v</sub> (m <sup>2</sup> )		W (mm)													
		200	250	300	350	400	450	500	600	700	800	900	1000	1100	1200
H (mm)	200	0,030	0,039	0,047	0,055	0,063	0,071	0,079	0,095	0,111	-	-	-	-	-
	250	0,040	0,050	0,061	0,072	0,082	0,093	0,103	0,125	0,146	0,167	-	-	-	-
	300	0,049	0,062	0,075	0,089	0,102	0,115	0,128	0,154	0,180	0,206	0,233	-	-	-
	350	0,059	0,074	0,090	0,105	0,121	0,137	0,152	0,183	0,215	0,246	0,277	0,308	-	-
	400	0,068	0,086	0,104	0,122	0,140	0,159	0,177	0,213	0,249	0,285	0,321	0,358	0,394	0,430
	450	-	0,098	0,119	0,139	0,160	0,180	0,201	0,242	0,283	0,325	0,366	0,407	0,448	0,489
	500	-	0,110	0,133	0,156	0,179	0,202	0,225	0,272	0,318	0,364	0,410	0,456	0,503	0,549
	600	-	-	0,162	0,190	0,218	0,246	0,274	0,330	0,387	0,443	0,499	0,555	0,611	0,668
	700	-	-	-	0,224	0,257	0,290	0,323	0,389	0,455	0,522	0,588	0,654	0,720	0,786
	800	-	-	-	-	0,296	0,334	0,372	0,448	0,524	0,600	0,677	0,753	0,829	0,905

**Free Area of GE1-S-SA1 Accessory**

A <sub>v</sub> (m <sup>2</sup> )		W (mm)													
		200	250	300	350	400	450	500	600	700	800	900	1000	1100	1200
H (mm)	200	0,029	0,037	0,044	0,052	0,060	0,067	0,075	0,090	0,106	-	-	-	-	-
	250	0,038	0,048	0,058	0,068	0,078	0,088	0,098	0,118	0,139	0,159	-	-	-	-
	300	0,047	0,059	0,072	0,084	0,097	0,109	0,121	0,146	0,171	0,196	0,221	-	-	-
	350	0,056	0,071	0,085	0,100	0,115	0,130	0,145	0,174	0,204	0,234	0,263	0,293	-	-
	400	0,065	0,082	0,099	0,116	0,133	0,151	0,168	0,202	0,237	0,271	0,305	0,340	0,374	0,409
	450	-	0,069	0,083	0,097	0,112	0,126	0,141	0,170	0,198	0,227	0,256	0,285	0,314	0,343
	500	-	0,077	0,093	0,109	0,125	0,142	0,158	0,190	0,222	0,255	0,287	0,320	0,352	0,384
	600	-	-	0,113	0,133	0,153	0,172	0,192	0,231	0,271	0,310	0,349	0,389	0,428	0,467
	700	-	-	-	0,157	0,180	0,203	0,226	0,272	0,319	0,365	0,411	0,458	0,504	0,551
	800	-	-	-	-	0,207	0,234	0,260	0,314	0,367	0,420	0,474	0,527	0,580	0,634

**Weights of S-SA1 Without Grille**

m (kg)		W (mm)													
		200	250	300	350	400	450	500	600	700	800	900	1000	1100	1200
H (mm)	200	7,3	8,0	8,6	9,3	9,9	10,6	11,2	12,5	13,9	-	-	-	-	-
	250	8,0	8,7	9,4	10,1	10,8	11,5	12,2	13,6	15,0	16,4	-	-	-	-
	300	8,6	9,3	10,1	10,8	11,6	12,3	13,1	14,6	16,1	17,6	19,1	-	-	-
	350	9,3	10,0	10,8	11,6	12,4	13,2	14,0	15,6	17,2	18,8	20,4	22,0	-	-
	400	9,9	10,7	11,6	12,4	13,3	14,1	15,0	16,6	18,3	20,0	21,7	23,4	25,1	26,7
	450	-	11,4	12,3	13,2	14,1	15,0	15,9	17,7	19,5	21,2	23,0	24,8	26,6	28,3
	500	-	12,1	13,1	14,0	15,0	15,9	16,9	18,7	20,6	22,5	24,3	26,2	28,1	29,9
	600	-	-	14,6	15,6	16,6	17,7	18,7	20,8	22,8	24,9	27,0	29,0	32,1	34,1
	700	-	-	-	16,5	18,3	19,4	20,6	22,8	25,1	27,4	30,6	32,9	35,1	37,4
	800	-	-	-	-	20,0	21,2	22,5	24,9	27,4	30,8	33,2	35,7	38,1	40,6

BST... m + 0,7kg

**Weights of S-SA1 with GE1-S-SA1 Accessory**


m (kg)		W (mm)													
		200	250	300	350	400	450	500	600	700	800	900	1000	1100	1200
H (mm)	200	7,4	8,1	8,8	9,4	10,1	10,8	11,5	12,8	14,2	-	-	-	-	-
	250	8,1	8,8	9,5	10,2	11,0	11,7	12,5	13,9	15,4	16,8	-	-	-	-
	300	8,7	9,5	10,3	11,1	11,9	12,6	13,4	15,0	16,6	18,1	19,7	-	-	-
	350	9,4	10,2	11,1	11,9	12,7	13,6	14,4	16,1	17,8	19,4	21,1	22,8	-	-
	400	10,1	11,0	11,9	12,7	13,6	14,5	15,4	17,2	19,0	20,8	22,5	24,3	26,1	27,8
	450	-	14,8	15,9	17,1	18,2	19,3	20,5	22,8	25,1	27,4	29,7	32,0	34,3	36,6
	500	-	18,1	19,5	20,8	22,2	23,5	24,9	27,6	30,3	33,0	35,7	38,4	41,1	43,8
	600	-	-	21,7	23,2	24,7	26,1	27,6	30,5	33,4	36,3	39,3	42,2	46,1	49,0
	700	-	-	-	27,9	30,3	32,0	33,8	37,2	40,6	44,0	48,4	51,8	55,3	58,6
	800	-	-	-	-	33,1	34,9	36,7	40,3	44,0	48,6	51,6	54,7	57,9	61,1

BST... m + 0,7kg

**NOTE:**

For activation types BST... add communication unit weight of 0,7 kg to the weight of S-SA1 (see table).

# Ordering Codes



## W - Width Dimension

200 mm, 250 mm, 300 mm, 350 mm, 400 mm, 450 mm, 500 mm, 600 mm, 700 mm, 800 mm, 900 mm, 1000 mm, 1100 mm, 1200 mm

## H - Height Dimensions

200 mm, 250 mm, 300 mm, 350 mm, 400 mm, 450 mm, 500 mm, 600 mm, 700 mm, 800 mm

## A - Type of Activation

**B230** - 230 V AC Belimo actuator

**B24** - 24 V AC/DC Belimo actuator

**B24-W** - 24 V AC/DC Belimo actuator & wire connector for supply and communication unit

**B24-SR** - 24 V AC/DC Belimo actuator, modulated (0) 2 V ... 10 V

**BST0** - 230 V AC supply and communication unit BKNE230-24 (2-wire to BKSE...) & 24 V AC/DC Belimo actuator

**BST1** - SLC powered supply and communication unit BC24-G2 (THC) & 24 V AC/DC Belimo actuator

**BST10** - 230 V AC supply and communication unit BKNE230-24-PL (Powerline) & 24 V AC/DC Belimo actuator

## Example of the Ordering Code

**S-SA1-800×450-B24-SR**

Smoke control damper with width of 800 mm and height of 450 mm, without a grille. Activated by a 24 V modulated Belimo actuator (0) 2 V ... 10 V.

# Product Handling

## Warning

Some damper parts can have sharp edges. To prevent injuries, use gloves when you install or move the damper. If you use or operate the damper incorrectly, there is a risk of:

- electric shock
- fire
- other damage

Ensure that installation is performed by a trained person. The S-SA1 is made of boards and sheet metal. Thus considered fragile. Be careful when you move the smoke control damper. Two people are necessary to move the dampers and put them onto the duct and/or hangers. It is necessary to move the bigger dampers with suitable lifting equipment (forklift, crane). Please follow both textual and graphic instructions.

### 1. Unpacking:

- Remove the packaging

### 2. Functionality check:

- Perform damper's functionality check (see "Operation Manual" section)

### 3. Placing the damper:

- Prepare the duct connection surfaces as per the desired installation type
- Fix the supports to the proper place as per chosen installation type
- Carefully lift the smoke control damper with the forklift, crane or manually
- Place the damper on the hangers and on duct connection surfaces


### 4. Fixing the damper:


**Note:** Make sure to continually check the alignment of the damper against the duct connection when performing the next steps.

- Fix the damper with duct by using suitable screws through the flange corners
- Verify there is no skewing of the damper body by measuring diagonal dimensions of the blade area or the nominal dimension


### 5. Finishing:

- Clean the damper from the debris and excess material from the insulation
- Connect the dampers actuator as per activation type wiring diagram in the "electrical connection" section
- Perform damper's functionality check (see "Operation Manual" section)
- Create and/or fill out the Operating Journal included with the smoke control damper (Operating Journal can be also downloaded at [design.systemair.com](http://design.systemair.com))









### Legend for Product Handling

- 1** - Smoke control damper S-SA1
- 2** - Connected ductwork tested according to EN 1366-9
- A1** - Extension with Grille (GE1-S-SA1) is not part of S-SA1 delivery
- F1** - Screw M8×20 mm (e.g. DIN 933)
- P4** - Holder for actuator
- P7** - Inspection lid






# Installation Methods

### Warning

- Suspension systems longer than 1,5 m require fire-resistant insulation
- Obey the applicable regulations and standards of the country that this product will be installed in
- Make sure that only approved personnel performs the installation
- Obey the written instructions and the illustrations in selected installation method

### Installation Rules

- The duct connected to the smoke control damper must be supported or hung in such a way that the damper does not carry its weight. The damper must not support any part of the surrounding construction or wall which could cause damage and consequent damper failure.
- Smoke control dampers can be suspended from solid ceiling slabs using adequately sized threaded rods. When using anchors in the ceiling, use a fire-rated anchor (with suitable a fire rating certificate).
- Easy access to mechanism and internal parts during inspection must be considered during damper placement
- The minimum distance between the smoke control damper bodies must be 200 mm (refer to Standard EN 1366-2)
- The minimum distance between the smoke control damper and the adjacent wall or ceiling must be 75 mm
- If the grilles are not original accessories, there must be a minimum clearance between the damper blade in its open position and self-standing grille. The clearance between the damper blade and these components must be at least 200 mm (refer to EN 1366-10).
- Lists of all permitted installation methods are provided in Handbook

 DMV	S-SA1 200 × 200 ... ... 1200 × 800	$E_{600} 120 (v_{ed} i \leftrightarrow o)$ $S1500 C_{MOD} AA_{single}$	<div>d) </div> <div>d) </div>	EN 1366-9	
 D1V					

NOTES:

- DMV** - Vertically Oriented Damper (in the Metal Duct)  
**D1V** - Vertically Oriented Damper (on the Duct)  
**d)** - Duct per EN 1366-9  
**v<sub>ed</sub>** - Duct placement, vertically oriented damper




# Installation DMV

## Vertically Oriented Damper, in the Metal Duct

1. Prepare the duct connection and the damper hangers.
  - a. Clean the connection surfaces. Make sure that the surfaces are even.
2. Obey the procedure in the “Product Handling” section to put the damper on its suspension system and against the connection surfaces.
3. Perform damper's functionality check (see "Operation Manual" section).


**IMPORTANT**

- Make sure that the closest hanger is placed not further than 50 mm from the duct connection
- If the hanger system is longer than 1,5 m, fire-resistant insulation is necessary (see hanger manufacturer instruction)
- Make sure that it is always possible to access the smoke control damper internally for maintenance. If necessary, make inspection panel in the connecting duct.
- Duct with lower resistivities will decrease the fire resistivity of smoke control damper
- The maximum fire resistance for in-duct installation is E<sub>600</sub> 120 with pressure level 3 (-1500 Pa ... 500 Pa)

 DMV	S-SA1 200 × 200 ... ... 1200 × 800	E <sub>600</sub> 120 (v <sub>ed</sub> i ↔ o) S1500 C <sub>MOD</sub> AAsingle	d) 	EN 1366-9	
---	--	---	---	-----------	--

**NOTES:**


- DMV** - Vertically Oriented Damper (in the Metal Duct)  
**d)** - Duct per EN 1366-9  
**v<sub>ed</sub>** - Duct placement, vertically oriented damper



#### Legend for Installation DMV

- 1 - Smoke control damper S-SA1
- 2 - Connected ductwork tested according to EN 1366-9
- A1 - Extension with Grille (GE1-S-SA1) is not part of S-SA1 delivery
- F1 - Screw M8×20 mm (e.g. DIN 933)

#### Damper Minimum Distances






# Installation D1V

## Vertically Oriented Damper, on the Duct

- 1. Prepare the duct connection and the damper hangers.
  - a. Clean the connection surfaces. Make sure that the surfaces are even.
- CAUTION:** The product label must remain clean and readable.
- 2. Obey the procedure in the “Product Handling” section to put the damper on its suspension system and against the connection surfaces.
- 3. Perform damper's functionality check (see "Operation Manual" section).


**IMPORTANT**

- Make sure that the closest hanger is placed not further than 50 mm from the duct connection
- If the hanger system is longer than 1,5 m, fire-resistant insulation is necessary (see hanger manufacturer instruction)
- Make sure that it is always possible to access the smoke control damper internally for maintenance. If necessary, make inspection panel in the connecting duct.
- Duct with lower resistivities will decrease the fire resistivity of smoke control damper
- The maximum fire resistance for in-duct installation is E<sub>600</sub> 120 with pressure level 3 (-1500 Pa ... 500 Pa)

 D1V	S-SA1 200 × 200 ... ... 1200 × 800	E <sub>600</sub> 120 (v <sub>ed</sub> i ↔ o) S1500 C <sub>MOD</sub> AAsingle	d) 	EN 1366-9	
---	--	---	--	-----------	--

**NOTES:**


- D1V** - Vertically Oriented Damper (on the Duct)
- d)** - Duct per EN 1366-9
- v<sub>ed</sub>** - Duct placement, vertically oriented damper



#### Legend for Installation D1V

- 1** - Smoke control damper S-SA1
- 2** - Connected ductwork tested according to EN 1366-9
- A1** - Extension with Grille (GE1-S-SA1) is not part of S-SA1 delivery
- F1** - Screw M8×20 mm (e.g. DIN 933)

## Damper Minimum Distances




# Electrical Connections

**WARNING**

- Risk of electric shock
  - Stop the power supply before you do work on electrical equipment
  - Only approved electricians can do work on the electrical system
- To access the electrical parts of this product follow instructions in "Product Handling" section

**Actuator Size Map of S-SA1**





## Electrical Parameters for Type of Activation and Actuator

AT	B	T (Nm)	NV (V)	F (Hz)	CO (W)	CR (W)	WS (VA)	WN
B230	BEN230	15	AC 230	50/60	4	0,4	7	I <sub>max</sub> 4 A @ 5 ms
	BEE230	25			3,5	0,4	6	I <sub>max</sub> 4 A @ 5 ms
	BE230	40			8	0,5	15	I <sub>max</sub> 7,9 A @ 5 ms
B24	BEN24	15	AC/DC 24	50/60	3	0,1	6	I <sub>max</sub> 8,2 A @ 5 ms
	BEE24	25			2,5	0,1	5	I <sub>max</sub> 8,2 A @ 5 ms
	BE24	40			12	0,5	18	I <sub>max</sub> 8,2 A @ 5 ms
B24-W	BEN24-ST	15	AC/DC 24	50/60	3	0,1	6	I <sub>max</sub> 8,2 A @ 5 ms
	BEE24-ST	25			2,5	0,1	5	I <sub>max</sub> 8,2 A @ 5 ms
	BE24-ST	40			12	0,5	18	I <sub>max</sub> 8,2 A @ 5 ms
B24-SR	BEN24-SR	15	AC/DC 24	50/60	3	0,3	6,5	I <sub>max</sub> 8,2 A @ 5 ms
	BEE24-SR	25			3	0,3	5,5	I <sub>max</sub> 8,2 A @ 5 ms
	-	-	-	-	-	-	-	-
BST0	BEN24-ST & BKNE230-24 <sup>(a)</sup>	15	AC 230	50/60	10	0,1	19	I <sub>max</sub> 8,2 A @ 5 ms
	BEE24-ST & BKNE230-24 <sup>(a)</sup>	25						
	BE24-ST & BKNE230-24 <sup>(a)</sup>	40						
BST1	BEN24-ST & BC24-G2 <sup>(a)</sup>	15	(SLC®)	-	3,5	0,5	12,5	-
	BEE24-ST & BC24-G2 <sup>(a)</sup>	25			3		12,5	-
	BE24-ST & BC24-G2 <sup>(a)</sup>	40			12,5		20	-
BST10	BEN24-ST & BKNE230-24-PL <sup>(a)</sup>	15	AC 230 (Powerline)	50/60	5	0,5	20	-
	BEE24-ST & BKNE230-24-PL <sup>(a)</sup>	25			4,5		20	-
	BE24-ST & BKNE230-24-PL <sup>(a)</sup>	40			14		20	-


## Legend for Electrical Parameters

**AT** - Activation type**B** - Belimo actuator type<sup>(a)</sup> - Supply and communication unit**T** - Torque**NV** - Nominal voltage**F** - Frequency**CO** - Consumption in operation**CR** - Consumption in rest**WS** - Wire sizing consumption**WN** - Wire sizing consumption note

### Type of Activation B230

- The circuit switch between wires 2 and 3 is not part of the damper supply.
- When the power supply is connected to wires 1 and 3, the actuator moves to the OPEN position.
- When the power supply is connected to wires 1 and 2, the actuator moves to the CLOSED position.

AC 230 V



#### CAUTION:

- Main power supply voltage! Danger of electric shock!
- Parallel connection of more actuators possible when the power consumption and switching threshold is observed!


### Legend for Activation Type B230

- 1** - Blue
- 2** - Brown
- 3** - White
- S1** - Violet
- S2** - Red
- S3** - White
- S4** - Orange
- S5** - Pink
- S6** - Grey

The Belimo BE230 actuator has wires without colours.

### Type of Activation B24

- The circuit switch between wires 2 and 3 is not part of the damper supply.
- When the power supply is connected to wires 1 and 3, the actuator moves to the OPEN position.
- When the power supply is connected to wires 1 and 2, the actuator moves to the CLOSED position.



#### CAUTION:

- Connect via safety isolation transformer!
- Parallel connection of more actuators possible when the power consumption and switching threshold is observed!


#### Legend for Activation Type B24

- 1** - Black
- 2** - Red
- 3** - White
- S1** - Violet
- S2** - Red
- S3** - White
- S4** - Orange
- S5** - Pink
- S6** - Grey

The Belimo BE24 actuator has wires without colours.

### Type of Activation B24-W

This type of activation has cable connectors (C1 and C2) for the supply and communication unit (the communication unit is not part of the mechanism).



#### CAUTION:

- Connect via safety isolation transformer!

#### Legend for Activation Type B24-W

The actuator has connection plugs C1 and C2.

**Cm** - Communication Module - not part of the delivery


**C1** - Supply: 3-pole plug that is applicable, for example to BKNE... or fs-UFC...

**C2** - Auxiliary switch: 6-pole plug that is applicable, for example to BKNE... or fs-UFC...

### Type of Activation B24-SR

This type of activation has modulating actuator that can be used for balancing/air flow control.

AC/DC 24 V



#### CAUTION:

- Connect via safety isolation transformer!
- Parallel connection of other actuators possible. Observe the performance data and the switching thresholds.
- Combination of power supply voltage and safety extra-low voltage not permitted at the both auxiliary switches.

#### Legend for Activation Type B24-SR

- 1** - Black
- 2** - Red
- 3** - White
- 5** - Orange
- S1** - Violet
- S2** - Red
- S3** - White
- S4** - Orange
- S5** - Pink
- S6** - Grey

Modulating function not available for belimo BE24 actuator.


### Type of Activation BST0

- The actuator and the control module are factory wired.
- Connect the supply voltage to the connecting cable (approx. 1 m, with ferrules).
- The 2-wire cable a|b to the BKSE24-6 is connected to terminals 6 and 7 (screw terminals for 2 x 1.5 mm<sup>2</sup> wire). Terminals 1 and 5 may not be assigned.
- The BKNE230-24 transmits the damper position OPEN|CLOSED and fault messages to the BKSE24-6. It receives the commands from the control unit BKSE24-6 and controls the actuator to the desired position.

### Two LEDs in the Device Indicate the Function Status

#### LED | Status | Function

Yellow	Flashing	Damper moves OPEN
Yellow	On	Damper OPEN
Green	Flashing	Damper moves CLOSED
Green	On	Damper CLOSED
Yellow and Green	Flashing at double frequency	Fault
Yellow and Green	Off	Power failure



#### CAUTION:

- Main power supply voltage! Danger of electric shock!
- Parallel connection of more actuators possible when the power consumption and switching threshold is observed!
- Combination of power supply voltage and safety extra-low voltage not permitted at the both auxiliary switches.

#### Legend for Activation Type BST0

**L (+)** - Brown

**N (-)** - Blue

**1)** - Supply voltage cable

**2)** - 2-wire cable

**a/b** - Connection to e.g. BKSE24-6

## Type of activation BST1

**IMPORTANT:** Danger of electric shock! Parallel circuits, i.e. a smoke detector on multiple slave devices are not allowed!

Switch off the power supply before working on any electrical equipment.

Allow only qualified electricians to work on the electrical system.

Actuator power supply via fitted communication unit: DC 24 V.

**NOTE:** Connection scheme for fitted communication and supply unit BC24-G2 (THC).

## LEDs Status Indication (BST1)

### LED colour | LED state | Status

Green | ON | Damper open

Green | Blinks | Damper is opening

Yellow | ON | Damper closed


Yellow | Blinks | Damper is closing

White | Blinks | SLC-communication ok – control command „close damper“

White | Flashes | SLC-communication ok – control command „open damper“

Red | ON | Safety element triggered (at X4)

Red | Blinks | self-test active; error: communication loss; error: actuator not connected; error: thermoelectric tripping device of actuator triggered; runtime monitoring error; mechanical error triggered



## Legend for Activation Type BST1

**X2** - 2-pin spring terminal: 1/2 - connection for SLC two-wire line, wires interchangeable. Maximum cable lengths can be calculated with the SLC Planning Tool. Rule of thumb: 300m@1.5 mm<sup>2</sup>.

**X3** - 3-pin connector: damper actuator (motor DC 24 V).



**X4** - 4-pin spring terminal: Connection for smoke detector.

- 1- (+) DC 24 V / max. 30 mA.
- 2- GND.
- 3- IN1 (external relay contact 1).
- 4- IN2 (external relay contact 2).

**X6** - 6-pin connector: damper actuator (position limit switches).

## Type of Activation BST10

**IMPORTANT:** Danger of electric shock! The BKNE230-24-PL may only be used with a designated master (e.g. BKS64-PL).

Switch off the power supply before working on any electrical equipment.

Allow only qualified electricians to work on the electrical system.

Actuator power supply via fitted communication unit: DC 24 V

**NOTE:** Connection scheme for fitted communication and supply unit BKNE230-24-PL (Powerline) with example of connection with ORS 142 K from Hekatron (smoke detector not part of delivery).

## LEDs status indication (BST10)

### LED colour | LED state | Status

Green | ON | Damper open

Green | Blinks | Damper is opening

Yellow | ON | Damper closed

Yellow | Blinks | Damper is closing

White TX | ON | PL data sent


White RX | ON | PL data received

Red | ON | Error saved

Red | Blinks | Error present

Blue | ON | Device in Bootloader mode

Blue | Blinks | Identified by the master



### Legend for Activation Type BST10

X6 and X300 connector terminals are arranged so that only either a conventional actuator or a Belimo Top-Line actuator can be connected.

**X200** - 2+2-pin spring terminal: (50/60Hz) AC 230 V with Powerline signal

**X3** - 3-pin connector: damper actuator (motor DC 24 V)

**X4** - 4-pin spring terminal: connection for smoke detector

**X6** - 6-pin connector: damper actuator (position limit switches)

**X8** - 3-pin spring terminal: connection for smoke detector (without smoke detector: connect +24 V and IN)

- 1- GND
- 2- (+) DC 24 V
- 3- IN

**X300** - 4-pin connector: connection for belimo top-line actuator (not used)

# Operation Manual


## Functionality Check


Before and after you install the damper, make sure that the damper's functionality is checked. The functionality is checked by:

1. Refer to the "Electrical connections" section to prepare the actuator connection.
2. Opening the damper:
  - Observe through grille or remove the grille and inspection opening lid by unscrewing two screws.
  - Depending on the activation type the opening follows based on the correct signal from e.g. BKSE24-6, correct voltage ( $Y = 10\text{ V}$ ) or by connecting supply wires as per wiring diagram, the actuator moves to the OPEN position.
  - The blade must move to the fully open position in 60 seconds or less. Then, the blade must stay locked.
  - After the blade is in its end position, the related signaling circuit sets to on. Make sure that you receive the open signal or wires S1 and S2 are connected.

**NOTE:** The actuator can be moved to open position with manual crank supplied with the actuator. Do not use drilling machine to turn the actuator.

3. Closing the damper:
  - Depending on the activation type the closing follows based on the correct signal from e.g. BKSE24-6, correct voltage ( $Y = 2\text{ V}$ ) or by connecting supply wires as per wiring diagram, the actuator moves to the CLOSED position.
  - The blade must move to the fully closed position in 60 seconds or less.
  - After the blade is in closed position, the related signaling circuit sets to on. Make sure that wires S4 and S6 are connected.
4. Put the damper into its operating position - "open" or "closed" based on the use of the product.
5. After the installation close the inspection opening with the removed lid with previously removed screws.





### Damper Inspection

**CAUTION:** Never perform inspection when there is air flowing in the duct connected to the smoke control damper.  
Do not change the dampers or their structure without the approval of the manufacturer.

The actuator keeps the dampers on stand-by during their life cycle. The operator obeys the applicable regulations and standards to do regular checks of the dampers. The recommended minimum interval for the inspection checks is 6 months. The manufacturer and/or government authorities must approve the inspecting person and/or process for this inspection. Operating Journal must be kept during the lifecycle of the smoke control damper. The damper's Operating Journal includes a copy of the approval/s of the inspecting person. If the inspecting person finds differences, the operator must write these differences in the Operating Journal. Then, he must recommend action to remove these differences.

After you install and start the damper, immediately do an initial check. This check obeys the same conditions as the six-month inspections.

Do a check of these elements of the external side of the damper:

- The damper housing
- The actuator movement.

**NOTE:** To do a visual check of the internal parts of the damper you may need to dismount the inspection lid or the grille. This will give you a better access to the internal parts.

Do a check of these items of the internal side of the damper:

- Make sure that there are no foreign objects or layers of contamination in the air distribution systems of the damper.
- The internal casing of the damper
- The sealings
- The foaming material
- The condition of the damper blade

- How accurately the damper blade closes when it is against the backstop in the closed position.

### Recommended Procedure for the Inspection Log (refer to EN 12101)

1. Find the identification of the damper.
  2. Write the date of the inspection.
  3. Examine the actuator wiring for damage.
  4. Examine the wiring of the end switches for damage.
  5. Make sure that the damper is clean. If necessary, clean the damper.
  6. Do a check of the inspection lid and of the tightness of the cover.
  7. Do a check of the blade and of the sealings. If necessary, correct the defects and record the results (where applicable).
  8. Do a functional test of the damper (open and close) (refer to the "Smoke Damper Functionality Check" chapter).
  9. Confirm the operation of the damper with the control system:
    - a. Monitor the physical performance of the damper
    - b. Monitor the signals of the end positions.
    - c. If necessary, correct and record the defect (where applicable).
  10. The damper is part of the SHEVS (Smoke and Heat Exhaust Ventilation System). Thus, you must do a check of the full system (refer to the Operational and Maintenance Requirements).
  11. Set the system to the operating position (refer to the "Operation Manual").
  12. Record the result in the "Operating Journal" with the name and the signature of the Inspection Technician.
- After the inspection, the inspecting person must write the data that follows in the "Operating Journal":

- Condition of the damper
- Date of the inspection
- Name, Surname and Signature of the employee that did the inspection (make sure that you can read this data).

## Supplement

Any deviations from the technical specifications contained on our website, handbook and the terms should be discussed with the manufacturer. We reserve the right to make any changes to the product without prior notice, provided that these changes do not affect the quality of the product and the required parameters. Current information on all products is available on [design.systemair.com](http://design.systemair.com).

