

## **Certyfikat Stałości Właściwości Użytkowych**

**1396 — CPR — 0112**

Zgodnie z Rozporządzeniem Parlamentu Europejskiego i Rady (UE) Nr 305/2011 z dnia 9 marca 2011 roku (Rozporządzenie Wyroby Budowlane lub CPR) niniejszy certyfikat dotyczy wyrobu budowlanego:

### **S-SA2 - Kłapa odcinająca wentylacji pożarowej, Systemair**

stosowane w warunkach opisanych w ocenie i weryfikacji stałości właściwości, Nr C1396/15/0026/4004/SC wydany przez FIRES, s.r.o., jednostkę notyfikowaną Nr 1396, w dniu 24-11-2015 zmieniony przez rzeczywisty raport ciągłego nadzoru

wprowadzony na rynek przez

**Systemair Production a.s., Hlavna 371, 900 43 Kalinkovo, SR**

I produkowany w fabryce

**Systemair Production a.s., Hlavna 371, 900 43 Kalinkovo, SR**

Niniejszy certyfikat potwierdza, że wszystkie postanowienia dotyczące oceny i weryfikacji stałości właściwości użytkowych, określone w załączniku ZA normy:

**EN 12101-8:2011**


W systemie 1 są zastosowane oraz że wyrób budowlany spełnia wszystkie określone wymagania dotyczące tych właściwości, oraz że zakładowa kontrola produkcji prowadzona przez producenta jest oceniana w celu zapewnienia

### **stałość właściwości użytkowych wyrobu budowlanego**

Niniejszy certyfikat został wydany po raz pierwszy 24-11-2015r. i pozostaje ważny tak długo, dopóki nie zmienią się metody badań i/lub wymagania dotyczące zakładowej kontroli produkcji zawarte w zharmonizowanej normie, zastosowane do oceny właściwości użytkowych zadeklarowanych charakterystyk oraz sam wyrób budowlany i warunki produkcji w zakładzie nie ulegną istotnym zmianom, chyba że zostaną zawieszony lub wycofany przez notyfikowaną jednostkę certyfikującą produkt.

Batizovce, 13-05-2019r. (-) pieczęć FIRES, s.r.o.

Podpis: inż. Maria Gasperowa Kierownik jednostki certyfikujące produkty



NOTIFIED BODY 1396  
Osloboditeľov 282, 059 35 Batizovce, Slovakia  
Tel.+421 52 285 1611, www.fires.sk



## Certificate of constancy of performance

**1396-CPR-0112**

In compliance with Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product

### **Systemair Smoke Control Damper S-SA2**

used on conditions described in the Assessment and verification of constancy of performance No. C1396/15/0026/4004/SC issued by FIRES, s.r.o., Notified Body 1396 on 24. 11. 2015, amended by an actual report of continuous surveillance

**placed on the market under the name or trade mark of**

**Systemair Production a. s., Hlavná 371, 900 43 Kalinkovo, SR**

**and produced in the manufacturing plant**

**Systemair Production a. s., Hlavná 371, 900 43 Kalinkovo, SR**

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard

**EN 12101-8: 2011**

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the

**constancy of performance of the construction product.**

This certificate was first issued on 24. 11. 2015 and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.

Batizovce, 13. 05. 2019



*Ing. Mária Gašperová*  
Ing. Mária Gašperová  
Head of Product Certification Body

090454

FIRES 136a/C-31/01/2017-E