
Access 5 communication manual



Table of contents

Chapter 1 About this document	4
Introduction	4
Software version	4
Chapter 2 System integration	5
BACnet IP	5
Modbus RTU/TCP	8
Watchdog	12
BMS outdoor temperature	13
Ethernet settings	14
Example of register addresses	17
Table of variables, objects and register addresses	18
APPENDIX	19

Chapter 1 About this document

Introduction

This document describes the communication capabilities of the Access Controller application when it is used as an integrated communication slave via BACnet and Modbus.

Software version

<i>Access version</i>	<i>Available</i>
V5.0-1-00	BACnet and Modbus available, not fully register/object compatibility with later releases.
V5.1-1-02 later	BACnet and Modbus are available

The Access variable list (release-column) states from which the software release variables are introduced or changed. Refer to APPENDIX with references to BACnet objects and Modbus registers.

Chapter 2 System integration

BACnet IP

From version 5.0-1-00 Access application is based on B-BC (BACnet Building Controller) protocol. Use the TCP/IP port to connect an Access application to a Building Management System (BMS) via BACnet/IP.

Configuration

Upon delivery, the BACnet/IP protocol is disabled as a default. To enable BACnet communication, login with ‘Service’ credentials, enable by changing the configuration for BACnet/IP from “No” to “Yes”. Then configure BACnet basic settings.



BACnet device name

In the Building Management System (BMS), the names of all located units are listed under. The Device name must be unique within the BACnet network.

BACnet device ID

The identification number (ID) of a unit identifies it on the BACnet network. The ID must be unique within the BACnet network.

BBMD address and BACnet/IP port number

The BACnet/IP Broadcast Management Device (BBMD) address to identify units that are connected to different BACnet/IP subnets and separated by an IP-router.

Enter the BBMD address as host:port. The host's name can be entered as "host" if the Domain System Name (DNS) is configured.

If the DNS is not configured, enter the host address in the format "xxx.xxx.xxx.xxx" followed by the communication port number (default: 47808).

Example: mybbmd:47808 (DNS configured), 10.100.50.99:47808.

Note! BACnet Broadcast Management Device (BBMD), are necessary to distribute broadcasts if BACnet/IP network uses several subnets.

Objects

Objects are available according to configured activated functions.

BACnet type

Abbreviations for objects used in the Access variable list:

AI = Analog Input

BI = Binary Input

MS = Schedule

AO = Analog Output

BO = Binary Output

MSV = Multistate Value

AV = Analog Value

BV = Binary Value

Properties

Following typically properties are writable: Cov Increment, Time Delay and limits. Typically used readable properties are Present Value, Event State, Time Delay, Low Limit, High Limit and Units.

COV subscriptions

COV property of objects are editable. Simultaneous COV subscriptions maximum is 100.

Out of service

BACnet objects for Analog Input and Binary Input has function "OutOfService" enabled.

With object out of service, it's possible to manually set Present Value with a value and this is equivalent to setting an input to "Manual" with NaviPad.

Note! With the out of service function AHU can run to infinity, depending on alarm configuration. User need to have knowledge about reasonable setting of manual set present values with regard to prevent any consequential damage to the machine, person or environment.

In order to continuously highlight for the user to remedy any defective sensor, an "input in manual" alarm is presented in alarm list in addition to sensor error alarm.

Priority array

Out-of-service is disabled on outputs, which instead uses priority array to determine the present value property. Priority array consists of 16 values where 1 has highest priority. For example when priority level 1 contains the value 25 and priority level 2 the value 40, the present value will be 25.

Access priority levels for outputs according to the following table:

Priority level	Usage	Remark
1	Manual life safety	
2	Automatic life safety	
3	Available	
4	Available	
5	Critical equipment control	
6	Minimum on/off	
7	Available	
8	Manual operator	Manual control
9	Manual operator	
10	Manual operator	
11	Manual operator	
12	Standard	From application
13	Available	
14	Available	
15	Available	
16	Available	

When priority level higher than 8 is used (1 – 7) it will be indicated in output status mode column with “BACnet”.

EDE files

EDE = "Engineering Data Exchange" is the format recommended by the BACnet Interest Group Europe to exchange data between BACnet server and BACnet client.

For offline integration there are EDE files containing information on the BACnet objects available for the Access control application.

Alarms

Alarm system is based on BACnet where alarming object, beyond alarm, can have high, low and fault depending on object type.

Time schedule

Function time schedule together with special days (holidays and exception days) is based on BACnet.

Modbus RTU/TCP

Configuration

TCP/IP

For Modbus TCP/IP communication, configure Modbus/TCP from “No” to “Yes” and set Modbus slave address.



For Modbus TCP, use the controller ethernet port combined with its IP address and the TCP port 502. The port number is not changeable.

RTU

For Modbus RTU, set Modbus slave address via the menu Modbus slave, configure communication settings via the menu for actual used communication port.



Configure the communication parameters for the Modbus-line first. The parameters defines the structure of messages and of the transmission speed. The parameters must be identical in both master and slave units.

The default configuration values of an Access controller are:

Slave address:	1
Word length:	8 bits
Parity:	none
Stop bits:	2 bits
Baud rate:	9600 bps

Slave address

A new Modbus slave address can be set for each air handling unit (AHU) via the menu Modbus slave with the NaviPad.

Communication limitations

There must be a minimum of 3.5 character times (4 ms at 9600 bps) between messages for the Modbus master unit.

Baud rate

Access application Control Unit supports following baud rates on RS485: 9600, 14 400, 19 200, 28 800, 38 400, 57 600, 76 800, 115 200 bps. The greater the transmission rate, the shorter the possible cable length is.

RS485

As Modbus RTU is based on RS485 bus following must be observed:

- Baud rate, parity and stop bits must match network and master.
- The bus wires A/B must not be crossed.
- In case of long distances or high baud rates, consider using end termination. See Modbus.org specification and implementation guide.

Transmission mode

Access uses the RTU transmission mode for the communication ports. However, the Modbus RTU transmission mode cannot understand messages using Modbus ASCII transmission mode. Therefore, the transmission mode must configure to be RTU in both the master unit and in the slave units.

The word parameter for the Modbus RTU transmission mode is 8 bits.

Address and registers

All Modbus addresses start with 0 except some Master-unit addresses that start with 1 (equal to register). For these Master-unit addresses it is necessary to add 1 to address.

Modbus type

Modbus register type and supported Modbus functions:

Register type	Functions	Register	Data type
Coil status	01=Read coils 05=Write single coil 15= Write multiple coils	0x	1 bit
Input status	02=Read discrete inputs	1x	1 bit
Input register	04=Read input register	3x	16-bit, 32-bit signed or unsigned
Holding register	03=Read holding register 06=Write single register 16=Write multiple registers	4x	16-bit, 32-bit signed or unsigned

Maximum 47 registers

A maximum of 47 registers can be read in one message.

Formats

Values and states are:

- Temperature, pressure, and flow 16- or 32-bit signed word
- States and statuses 16-bit unsigned word

32-bit word presented as huge or float consists of two 16-bit registers. Double word, where Register 0 is most significant (MSW) and Register 1 is least significant (LSW).

States are presented as a number, enumerated type. Texts for each state are presented in the description's column for the first object in a series of same enumerated type.

Scale factor

Most real variables have scale factor 10. Exceptions are time setting (scale factor 100) and air flow (scale factor 1). Also, Integer, Index and Logic always have scale factor 1.

For example, a temperature value with scale factor 10 can be interpreted to be a value with 1 decimal, while a temperature integer value with scale factor 1 will have no decimal.

Scale factors for real variables are listed in the Scale factor column.

Units

Values of real variables each have an engineering unit as per selected preference setting in the controller. Character in table represents preference dependent unit for:

P (pressure) = Pa, in.wg

T (temperature) = °C, °F

Q (flow) = m³/h, CFM, m³/s, l/s

SFP=kW/m³/s

Alarms

Alarm system is based on BACnet. Alarming objects are available on Modbus registers with alarm status. Alarm status as enumerated types, available depending on object type.

Alarm acknowledgement can be done with two different registers. Either acknowledge all alarms with a Coil register or individual, writing the alarm id/number in a Holding register.

Time schedule

Function time schedule is based on BACnet. Local time schedule settings for Monday – Sunday is available on Modbus.

Each day can be defined with maximum 8 events per day where events, as enumerated types, depending on configured fan levels.

Watchdog

The Access application (from version 5.0-1-00) can supervise communication received from a Building Management System (BMS) master unit.


A single slave communication protocol can be monitored at a time.

An alarm message generates if there is no active communication from the Building Management System (BMS) master unit is detected before the watchdog timeout runs out.

BMS watchdog (Activation of protocol)

Upon delivery, the Building Management System (BMS) watchdog is disabled as default.

To activate and configure the BMS watchdog go to Configuration > System settings > Communication > BMS watchdog in the web controller menu. The below screen displays:



BMS protocol

The default setting for BMS protocol is “None”.

To activate the BMS watchdog, change the BMS protocol setting to the protocol used for BMS communication. Supported protocols are Modbus and BACnet.

Watchdog timeout

The BMS watchdog timeout period can be set between 10-3600 seconds. The BMS watchdog timeout is by default set to 60 seconds.

If the byte counter of received bytes does not change during the watchdog timeout, the communication is considered faulty and an alarm message generates.

Communication fault BMS master

When a communication fault is detected, all values generated by the BMS are considered invalid. By default, the alarm is set to “Class C with no action”.

BMS outdoor temperature

The Access application (from software version 5.0-1-00) is capable of receiving external outdoor air temperature reference from BMS via Modbus and BACnet.

Function


When BMS outdoor temperature is used the application uses the value from the Modbus Holding register or BACnet object.

The BMS watchdog in the application supervises that value is valid and updated. In case of communication fault according the BMS watchdog both a sensor error alarm for BMS Outdoor temperature and a watchdog alarm are generated.

When BMS outdoor temperature is not valid the control functions consider it as an <Invalid> value until BMS values is updated and sensor error and watchdog alarm returned.

Configuration

Allocate the analog input for outdoor temperature to the Device=BMS.



Ethernet settings

The NaviPad and Access control unit can be connected without a DHCP server via a switch module or the dedicated HMI port on the control unit. Auto-IP (link-local) addresses are automatically assigned to the NaviPad and control unit. Addresses are randomly assigned from within the range: 169.254.x.y (255.255.0.0).

Static IP-addresses, as opposed to dynamic (DHCP), can be used in Access (from version 4.0-1-04) and in NaviPad (from version 1.1.0.184).

Two individual IP-addresses are required when an the control unit of an air handling unit (AHU) is linked with a NaviPad. One IP-address must be assigned to each unit. Refer to applicable IT Department for addresses.

The below steps **MUST** be followed when static IP-addresses are integrated and configured.

To manually set a static IP-address (between NaviPad and an air handling unit (AHU)):

1. From NaviPad, log in to the AHU web page.
2. Click to enable the static IP-addresses to be set via the AHU web interface.
3. Enter the IP, subnet mask, gateway and DNS-address in the AHU control unit as applicable.
4. Click to save new settings.
5. Press the NaviPad home button to log out of AHU web page. The NaviPad loses the connection with the AHU.
6. Go to the NaviPad settings. In the NaviPad settings, go to Advanced HMI > Ethernet. Log in (default password: 1111).
7. Activate the switch function to enable static IP-address setting.
8. Edit the IP-address, subnet mask and gateway as applicable.
9. Use NaviPad to search for available units if needed.

NOTE: The air handling unit (AHU), the NaviPad and any additional devices must be connected to a local network within the same IP-subnet.

NOTE: If no gateway is available, use either 0.0.0.0 or same as the IP-address set for the unit.

DHCP

The Dynamic Host Configuration Protocol (DHCP) is a network protocol used for dynamic distribution of network configuration parameters, for example IP-addresses and DNS servers. The control unit of the Access application can be configured to receive an IP-address from a DHCP-server (dynamic) or have the address configured manually (static).

To configure the Access controller unit with a static IP-address use the controller web-interface (from Access version 4.0-1-04):

- 1) Enter applicable IP-address.
- 2) Enter applicable subnet mask.
- 3) Enter applicable gateway address.
- 4) Enter applicable XXX (DNS) server address.


Access application control unit


The ethernet settings display in the Access web menu (from version 5.0-1-00):



NaviPad


The ethernet NaviPad settings display in the NaviPad web menu (from version 1.1.0.184):





Example of register addresses

Example of useful register addresses in a flow chart for an air handling unit (AHU) with a rotary exchanger, heater, and a cooling unit.



Alarm point-status			event-state Status/values			present-value			Commands/setpoints			present-value		
Modbus	Description	BACnet	Modbus	Description	BACnet	Modbus	Description	BACnet	Modbus	Description	BACnet	Modbus	Description	BACnet
3x0716	Freeze protection alarm	AI:17	1x0210	Sequence-A/heating pump start	BO:11	0x0000	Acknowledge all alarms	BV:8	3x0754	Control unit battery error	BV:48	1x0212	Sequence-C/cooling pump start	BO:13
3x0755	Communication fault device	BV:49	1x0220	Supply air fan start	BO:21	4x0699	Acknowledge alarm no.	MSV:31	3x0756	Internal error	BV:50	1x0221	Extract air fan start	BO:22
3x0761	Malfunction pump sequence-A	BV:65	3x0031	Actual value intake air temperature	AI:2	4x0521	Temperature control type	MSV:14	3x0763	Malfunction pump sequence-C	BV:47	3x0032	Actual value supply air temperature	AI:3
3x0776	Rotary exchanger alarm	BV:47	3x0033	Actual value exhaust air temperature	AI:4	4x0524	Max limit supply air (cascade ctrl.)	AV:41	3x0782	Filter alarm supply air	BI:30	3x0034	Actual value extract air temperature	AI:5
3x0783	Filter alarm extract air	BI:31	3x0039	Actual value supply air pressure	AI:10	4x0586	Alarm limit freeze protection 1	AV:206	3x0784	Low efficiency exchanger	AV:427	3x0040	Actual value extract air pressure	AI:11
3x0797	Deviation alarm supply air temperature	AV:425	3x0041	Actual value exch-extract pressure	AI:15	4x0600	Alarm low limit exchanger efficiency	AV:427	3x0810	Fire alarm	BV:63	3x0043	Actual value freeze protection temp	AI:17
3x0834	Deviation alarm supply air fan	AV:428	3x0055	Actual value supply air filter pressure	AI:34	4x0666	Outdoor temperature from BMS	AV:466	3x0835	Deviation alarm extract air fan	AV:429	3x0056	Actual value extract air filter pressure	AI:35
3x0836	Service stop	BV:38	3x0057	Actual value efficiency temperature	AI:36	Temperature setpoint according control type:								
3x0837	Warning freeze protection	BV:39	3x0078	Calculated average room temperature	AV:257	4x0522	Supply air temperature	AV:39	3x0838	Malfunction supply air fan	BV:82	3x0110	Actual value supply air flow	AI:12
3x0847	Defrosting guard exchanger	BI:24	3x0112	Actual value extract air flow	AI:13	4x0523	Extract air temperature	AV:40	3x0856	Defrosting alarm	BV:62	3x0166	Actual output sequence-A	AO:1
3x0857	Malfunction supply air fan	BV:82	3x0167	Actual output sequence-B	AO:2	4x0585	Room temperature	AV:184	3x0858	Malfunction extract air fan	BV:8	3x0178	Actual output supply air fan	AO:13
3x0858	Malfunction extract air fan	BV:8	3x0168	Actual output sequence-C	AO:3	4x0587	Freeze protection 1 standby	AV:188	3x0179	Actual output extract air fan	AO:14	3x0200	Calculated temp efficiency exchanger	AV:427
Status/values			present-value			Fan level air flow setpoint:			Fan level air pressure setpoint:			Fan level air pressure setpoint:		
1x0000	Unacknowledged alarm	BV:9	3x0179	Actual output extract air fan	AO:14	4x0900	Flow setpoint supply air fan low speed	AV:53	4x0536	Pressure setpoint supply air fan low.sp	AV:47	4x0537	Pressure setpoint supply air fan normal	AV:48
1x0001	Unacknowledged A-alarm	BV:10	3x0200	Calculated temp efficiency exchanger	AV:427	4x0902	Flow setpoint supply air fan normal sp	AV:54	4x0538	Pressure setpoint supply air fan high.sp	AV:49	4x0539	Pressure setpoint extract air fan low.sp	AV:50
1x0002	Unacknowledged B-alarm	BV:11				4x0904	Flow setpoint supply air fan high sp	AV:55	4x0540	Pressure setpoint extract air fan normal	AV:51	4x0541	Pressure setpoint extract air fan high.sp	AV:52
1x0003	Unacknowledged C-alarm	BV:12				4x0906	Flow setpoint extract air fan low speed	AV:56						
3x0201	Actual unit mode	MSV:15				4x0908	Flow setpoint extract air fan normal sp	AV:57						
3x0202	Indication triggering run mode	MSV:16				4x0910	Flow setpoint extract air fan high sp	AV:58						
3x0243	Actual SFP	AV:283												
3x0244	Average SFP (day)	AV:284												
3x0245	Average SFP (30 days)	AV:285												

Table of variables, objects and register addresses

The most used within a SCADA in a flow chart together with local time channel settings system, refer to the Access variable list under APPENDIX. This and a full unfiltered Access list together with EDE files can be delivered upon request. Contact Technical Support.

APPENDIX



Access variable list

Access version: 5.2-1-00 rev. 1

Function	Description	Data Type	Modbus type	Modbus address	RW	Bacnet	Scale factor	Unit	Release
Actual values	Sum alarm: Unacknowledged A-, B- or C-alarm	Digital	Input Status Register (1x)	0000	R	BV:9	1		
Actual values	Sum alarm: Unacknowledged A-alarm	Digital	Input Status Register (1x)	0001	R	BV:10	1		
Actual values	Sum alarm: Unacknowledged B-alarm	Digital	Input Status Register (1x)	0002	R	BV:11	1		
Actual values	Sum alarm: Unacknowledged C-alarm	Digital	Input Status Register (1x)	0003	R	BV:12	1		
Actual values	SEQ-A pump start	Digital	Input Status Register (1x)	0210	R	BO:11	1		
Actual values	SEQ-B pump start	Digital	Input Status Register (1x)	0211	R	BO:12	1		
Actual values	SEQ-C pump start	Digital	Input Status Register (1x)	0212	R	BO:13	1		
Actual values	SEQ-D pump start	Digital	Input Status Register (1x)	0213	R	BO:14	1		
Actual values	SEQ-E pump start	Digital	Input Status Register (1x)	0214	R	BO:15	1		
Actual values	SEQ-F pump start	Digital	Input Status Register (1x)	0215	R	BO:16	1		
Actual values	SEQ-G pump start	Digital	Input Status Register (1x)	0216	R	BO:17	1		
Actual values	SEQ-H pump start	Digital	Input Status Register (1x)	0217	R	BO:18	1		
Actual values	SEQ-I pump start	Digital	Input Status Register (1x)	0218	R	BO:19	1		
Actual values	SEQ-J pump start	Digital	Input Status Register (1x)	0219	R	BO:20	1		



Actual values	Supply air fan start	Digital	Input Status Register (1x)	0220	R	BO:21	1		
Actual values	Extract air fan start	Digital	Input Status Register (1x)	0221	R	BO:22	1		
Actual values	Actual value outdoor temperature	16-bit	Input Register (3x)	0030	R	AI:1	10	T	
Actual values	Actual value intake air temperature	16-bit	Input Register (3x)	0031	R	AI:2	10	T	
Actual values	Actual value supply air temperature	16-bit	Input Register (3x)	0032	R	AI:3	10	T	
Actual values	Actual value exhaust air temperature	16-bit	Input Register (3x)	0033	R	AI:4	10	T	
Actual values	Actual value extract air temperature	16-bit	Input Register (3x)	0034	R	AI:5	10	T	
Actual values	Actual value supply air pressure	16-bit	Input Register (3x)	0039	R	AI:10	10	T	
Actual values	Actual value extract air pressure	16-bit	Input Register (3x)	0040	R	AI:11	10	T	
Actual values	Actual value exchanger extract pressure	16-bit	Input Register (3x)	0041	R	AI:15	10	T	
Actual values	Actual value freeze protection temperature 1	16-bit	Input Register (3x)	0043	R	AI:17	10	T	
Actual values	Actual value CO ₂ room/extract air	16-bit	Input Register (3x)	0046	R	AI:20	10	ppm	
Actual values	Actual value supply air filter pressure	16-bit	Input Register (3x)	0055	R	AI:34	10	P	
Actual values	Actual value extract air filter pressure	16-bit	Input Register (3x)	0056	R	AI:35	10	P	
Actual values	Actual value efficiency temperature	16-bit	Input Register (3x)	0057	R	AI:36	10	T	
Actual values	Calculated average temperature of room sensor 1 to 4	16-bit	Input Register (3x)	0078	R	AV:257	10	T	
Actual values	Actual value supply air flow	32-bit	Input Register (3x)	0110	R	AI:12	1	Q	
Actual values	Actual value extract air flow	32-bit	Input Register (3x)	0112	R	AI:13	1	Q	
Actual values	Actual value SEQ-A	16-bit	Input Register (3x)	0166	R	AO:1	10	%	
Actual values	Actual value SEQ-B	16-bit	Input Register (3x)	0167	R	AO:2	10	%	
Actual values	Actual value SEQ-C	16-bit	Input Register (3x)	0168	R	AO:3	10	%	
Actual values	Actual value SEQ-D	16-bit	Input Register (3x)	0169		AO:4	10	%	
Actual values	Actual value SEQ-E	16-bit	Input Register (3x)	0170		AO:5	10	%	
Actual values	Actual value SEQ-F	16-bit	Input Register (3x)	0171		AO:6	10	%	
Actual values	Actual value SEQ-G	16-bit	Input Register (3x)	0172		AO:7	10	%	
Actual values	Actual value SEQ-H	16-bit	Input Register (3x)	0173		AO:8	10	%	
Actual values	Actual value SEQ-I	16-bit	Input Register (3x)	0174		AO:9	10	%	
Actual values	Actual value SEQ-J	16-bit	Input Register (3x)	0175		AO:10	10	%	
Actual values	Actual value supply air fan	16-bit	Input Register (3x)	0178	R	AO:13	10	%	

Actual values	Actual value extract air fan	16-bit	Input Register (3x)	0179	R	AO:14	10	%	
Actual values	Calculated temperature efficiency exchanger	16-bit	Input Register (3x)	0200	R	AV:427	10	%	
Actual values	Actual unit modeModbus0= Stop1= Starting up2= Low speed3= Normal speed4= High speed5= Support heating6= Support cooling7= CO28= Free cooling9= Cool down10= Fire11= Smoke12= Recirculation13= DefrostingBacnet present-value+1 offset for corresponding Modbus	16-bit	Input Register (3x)	0201	R	MSV:15	1		
Actual values	Indicates what is triggering the current run modeModbus0= Time schedule1= Manual run2= Digital input3= Alarm4= External control5= Service stopBacnet present-value+1 offset for corresponding Modbus	16-bit	Input Register (3x)	0202	R	MSV:16	1		

Actual values	Control PID signal SEQ-A	16-bit	Input Register (3x)	0214	R	AV:467	10	%	
Actual values	Control PID signal SEQ-B	16-bit	Input Register (3x)	0215	R	AV:468	10	%	
Actual values	Control PID signal SEQ-C	16-bit	Input Register (3x)	0216	R	AV:469	10	%	
Actual values	Control PID signal supply air fan	16-bit	Input Register (3x)	0224	R	AV:265	10	%	
Actual values	Control PID signal extract air fan	16-bit	Input Register (3x)	0225	R	AV:266	10	%	
Actual values	Actual setpoint supply air temperature	16-bit	Input Register (3x)	0234	R	AV:273	10	T	
Actual values	Actual setpoint supply air fan	16-bit	Input Register (3x)	0235	R	AV:274	10	T	
Actual values	Actual setpoint extract air fan	16-bit	Input Register (3x)	0236	R	AV:275	10	P/Q	
Actual values	Actual SFP	16-bit	Input Register (3x)	0243	R	AV:283	10	SFP	
Actual values	Average SFP (day)	16-bit	Input Register (3x)	0244	R	AV:284	10	SFP	
Actual values	Average SFP (30 days)	16-bit	Input Register (3x)	0245	R	AV:285	10	SFP	
Alarm status	Alarm 2085 freeze protection temperature 1 Modbus alarm-status 0= normal 1= fault 2= alarm 3= high limit 4= low limit 6= acknowledged 7= blocked 8= returned	16-bit	Input Register (3x)	0716	R	AI:17	1		
Alarm status	Alarm 3075 internal battery error	16-bit	Input Register (3x)	0754	R	BV:48	1		
Alarm status	Alarm 3080 communication fault with device	16-bit	Input Register (3x)	0755	R	BV:49	1		
Alarm status	Alarm 3090 internal error	16-bit	Input Register (3x)	0756	R	BV:50	1		
Alarm status	Alarm 3020 malfunction sequence-A	16-bit	Input Register (3x)	0761	R	BV:65	1		
Alarm status	Alarm 3025 malfunction sequence-B	16-bit	Input Register (3x)	0762	R	BV:66	1		
Alarm status	Alarm 3030 malfunction sequence-C	16-bit	Input Register (3x)	0763	R	BV:67	1		
Alarm status	Alarm 3035 malfunction sequence-D	16-bit	Input Register (3x)	0764	R	BV:68	1		
Alarm status	Alarm 3040 malfunction sequence-E	16-bit	Input Register (3x)	0765	R	BV:69	1		
Alarm status	Alarm 3045 malfunction sequence-F	16-bit	Input Register (3x)	0766	R	BV:70	1		

Alarm status	Alarm 3050 malfunction sequence-G	16-bit	Input Register (3x)	0767	R	BV:71	1		
Alarm status	Alarm 3055 malfunction sequence-H	16-bit	Input Register (3x)	0768	R	BV:72	1		
Alarm status	Alarm 3060 malfunction sequence-I	16-bit	Input Register (3x)	0769	R	BV:73	1		
Alarm status	Alarm 3065 malfunction sequence-J	16-bit	Input Register (3x)	0770	R	BV:74	1		
Alarm status	Alarm 3070 rotary exchanger alarm	16-bit	Input Register (3x)	0776	R	BV:47	1		
Alarm status	Alarm 1000 filter guard supply air	16-bit	Input Register (3x)	0782	R	BI:30	1		
Alarm status	Alarm 1005 filter guard extract air	16-bit	Input Register (3x)	0783	R	BI:31	1		
Alarm status	Alarm 1070 low efficiency exchanger	16-bit	Input Register (3x)	0784	R	AV:427	1		
Alarm status	Alarm 1080 deviation supply air temperature	16-bit	Input Register (3x)	0797	R	AV:425	1		
Alarm status	Alarm 6010 fire alarm	16-bit	Input Register (3x)	0810	R	BV:63	1		
Alarm status	Alarm 1015 deviation supply air fan	16-bit	Input Register (3x)	0834	R	AV:428	1		
Alarm status	Alarm 1020 deviation extract air fan	16-bit	Input Register (3x)	0835	R	AV:429	1		
Alarm status	Alarm 7015 service stop	16-bit	Input Register (3x)	0836	R	BV:38	1		
Alarm status	Alarm 7020 warning freeze protection	16-bit	Input Register (3x)	0837	R	BV:39	1		
Alarm status	Alarm 1060 defrosting guard exchanger	16-bit	Input Register (3x)	0847	R	BI:24	1		
Alarm status	Alarm 1105 defrosting alarm	16-bit	Input Register (3x)	0856	R	BV:62	1		
Alarm status	Alarm 3145 malfunction supply air fan	16-bit	Input Register (3x)	0857	R	BV:82	1		
Alarm status	Alarm 3150 malfunction extract air fan	16-bit	Input Register (3x)	0858	R	BV:83	1		
Commands & setpoints	Acknowledge all alarms	Digital	Coil Status Register (0x)	0000	RW	BV:8	1		
Commands & setpoints	Reset the alarm service interval counter	Digital	Coil Status Register (0x)	0001	RW	BV:6	1		

Commands & setpoints	External control Modbus 0= None 1= Extended run low 2= Extended run normal 3= Extended run high 4= External stop 5= External stop with support control 6= Free cooling start 7= Recirculation Bacnet present-value +1 offset for corresponding Modbus	16-bit	Holding Register (4x)	0510	RW	MSV:31	1		
Commands & setpoints	Temperature control type Modbus 0= Supply air 1= Supply air outdoor compensated 2= Room cascade 3= Extract air cascade 4= Room (summer) else supply air 5= Extract air (summer) else supply air 6= Room cascade outdoor compensated 7= Extract air cascade outdoor comp. 8= Extract air dependent supply air temp. Bacnet present-value +1 offset for corresponding Modbus	16-bit	Holding Register (4x)	0521	RW	MSV:14	1		
Commands & setpoints	Temperature setpoint according control type: supply air	16-bit	Holding Register (4x)	0522	RW	AV:39	10	T	
Commands & setpoints	Temperature setpoint according control type: extract air	16-bit	Holding Register (4x)	0523	RW	AV:40	10	T	
Commands & setpoints	Temperature setpoint cascade control: max limit supply air	16-bit	Holding Register (4x)	0524	RW	AV:41	10	T	
Commands & setpoints	Temperature setpoint cascade control: min limit supply	16-bit	Holding Register (4x)	0525	RW	AV:42	10	T	
Commands & setpoints	Fan level air pressure setpoint: supply low speed	16-bit	Holding Register (4x)	0536	RW	AV:47	10	P	

Commands & setpoints	Fan level air pressure setpoint: supply normal speed	16-bit	Holding Register (4x)	0537	RW	AV:48	10	P	
Commands & setpoints	Fan level air pressure setpoint: supply high speed	16-bit	Holding Register (4x)	0538	RW	AV:49	10	P	
Commands & setpoints	Fan level air pressure setpoint: extract low speed	16-bit	Holding Register (4x)	0539	RW	AV:50	10	P	
Commands & setpoints	Fan level air pressure setpoint: extract normal speed	16-bit	Holding Register (4x)	0540	RW	AV:51	10	P	
Commands & setpoints	Fan level air pressure setpoint: extract high speed	16-bit	Holding Register (4x)	0541	RW	AV:52	10	P	
Commands & setpoints	Temperature settting: min limit outdoor during day to allow start free cooling	16-bit	Holding Register (4x)	0563	RW	AV:164	10	T	
Commands & setpoints	Temperature setting: max limit outdoor during night to stop free cooling	16-bit	Holding Register (4x)	0564	RW	AV:165	10	T	
Commands & setpoints	Temperature setting: min limit outdoor during night to stop free cooling	16-bit	Holding Register (4x)	0565	RW	AV:166	10	T	
Commands & setpoints	Temperature setting: min limit room temperature during night to stop free cooling	16-bit	Holding Register (4x)	0566	RW	AV:167	10	T	
Commands & setpoints	CO ₂ setpoint mixing damper function	16-bit	Holding Register (4x)	0571	RW	AV:170	10	ppm	
Commands & setpoints	Temperature setpoint according control type: room temperature	16-bit	Holding Register (4x)	0585	RW	AV:184	10	T	
Commands & setpoints	Alarm limit freeze protection 1	16-bit	Holding Register (4x)	0586	RW	AV:206	10	T	
Commands & setpoints	Temperature setpoint according control type: freeze protection 1 if standby	16-bit	Holding Register (4x)	0587	RW	AV:188	10	T	
Commands & setpoints	Alarm low limit exchanger efficiency	16-bit	Holding Register (4x)	0600	RW	AV:427	10	T	
Commands & setpoints	Temperature setpoint: supply air temperature summer	16-bit	Holding Register (4x)	0660	RW	AV:45	10	T	
Commands & setpoints	Temperature setpoint: outdoor temp. summer/winter switch	16-bit	Holding Register (4x)	0661	RW	AV:46	10	T	
Actual values	Outdoor temperature sent from BMS system	16-bit	Holding Register (4x)	0666	RW	AV:466	10	T	
Commands & setpoints	Acknowledge alarm number	16-bit	Holding Register (4x)	0699	RW		1		
Commands & setpoints	Time setting: minutes to block heat output after free cooling	32-bit	Holding Register (4x)	0800	RW	PIV:1	1	m	
Commands & setpoints	Time setting: start hour free cool function	32-bit	Holding Register (4x)	0828	RW	PIV:73	1	h	
Commands & setpoints	Time setting: stop hour free cool function	32-bit	Holding Register (4x)	0830	RW	PIV:74	1	h	
Commands & setpoints	Fan level air flow setpoint: supply low speed	32-bit	Holding Register (4x)	0900	RW	AV:53	1	Q	
Commands & setpoints	Fan level air flow setpoint: supply normal speed	32-bit	Holding Register (4x)	0902	RW	AV:54	1	Q	
Commands & setpoints	Fan level air flow setpoint: supply high speed	32-bit	Holding Register (4x)	0904	RW	AV:55	1	Q	

Commands & setpoints	Fan level air flow setpoint: extract low speed	32-bit	Holding Register (4x)	0906	RW	AV:56	1	Q	
Commands & setpoints	Fan level air flow setpoint: extract normal speed	32-bit	Holding Register (4x)	0908	RW	AV:57	1	Q	
Commands & setpoints	Fan level air flow setpoint: extract high speed	32-bit	Holding Register (4x)	0910	RW	AV:58	1	Q	
Time channel	Real time clock: Minute 0-59	16-bit	Holding Register (4x)	0000	RW		1		
Time channel	Real time clock: Hour 0-23	16-bit	Holding Register (4x)	0001	RW		1		
Time channel	Real time clock: Day of Week 1-7, 1=Monday	16-bit	Holding Register (4x)	0002	RW		1		
Time channel	Real time clock: Week number 1-53	16-bit	Holding Register (4x)	0003	RW		1		
Time channel	Real time clock: Day of month 1-31	16-bit	Holding Register (4x)	0004	RW		1		
Time channel	Real time clock: Month 1-12	16-bit	Holding Register (4x)	0005	RW		1		
Time channel	Real time clock: Year 0-99	16-bit	Holding Register (4x)	0006	RW		1		
Time channel	Monday: event 1 Modbus 1: stop 2: low speed 3: normal speed 4: high speed	16-bit	Holding Register (4x)	0007	RW	MS:2	1		
Time channel	Monday: event 2	16-bit	Holding Register (4x)	0008	RW	MS:2	1		
Time channel	Monday: event 3	16-bit	Holding Register (4x)	0009	RW	MS:2	1		
Time channel	Monday: event 4	16-bit	Holding Register (4x)	0010	RW	MS:2	1		
Time channel	Monday: event 1 time of day (HH:MM)	16-bit	Holding Register (4x)	0063	RW	MS:2	100		
Time channel	Monday: event 2 time of day	16-bit	Holding Register (4x)	0064	RW	MS:2	100		
Time channel	Monday: event 3 time of day	16-bit	Holding Register (4x)	0065	RW	MS:2	100		
Time channel	Monday: event 4 time of day	16-bit	Holding Register (4x)	0066	RW	MS:2	100		
Time channel	Tuesday: event 1	16-bit	Holding Register (4x)	0015	RW	MS:2	1		
Time channel	Tuesday: event 2	16-bit	Holding Register (4x)	0016	RW	MS:2	1		
Time channel	Tuesday: event 3	16-bit	Holding Register (4x)	0017	RW	MS:2	1		
Time channel	Tuesday: event 4	16-bit	Holding Register (4x)	0018	RW	MS:2	1		
Time channel	Tuesday: event 1 time of day	16-bit	Holding Register (4x)	0071	RW	MS:2	100		
Time channel	Tuesday: event 2 time of day	16-bit	Holding Register (4x)	0072	RW	MS:2	100		

Time channel	Tuesday: event 3 time of day	16-bit	Holding Register (4x)	0073	RW	MS:2	100		
Time channel	Tuesday: event 4 time of day	16-bit	Holding Register (4x)	0074	RW	MS:2	100		
Time channel	Wednesday: event 1	16-bit	Holding Register (4x)	0023	RW	MS:2	1		
Time channel	Wednesday: event 2	16-bit	Holding Register (4x)	0024	RW	MS:2	1		
Time channel	Wednesday: event 3	16-bit	Holding Register (4x)	0025	RW	MS:2	1		
Time channel	Wednesday: event 4	16-bit	Holding Register (4x)	0026	RW	MS:2	1		
Time channel	Wednesday: event 1 time of day	16-bit	Holding Register (4x)	0079	RW	MS:2	100		
Time channel	Wednesday: event 2 time of day	16-bit	Holding Register (4x)	0080	RW	MS:2	100		
Time channel	Wednesday: event 3 time of day	16-bit	Holding Register (4x)	0081	RW	MS:2	100		
Time channel	Wednesday: event 4 time of day	16-bit	Holding Register (4x)	0082	RW	MS:2	100		
Time channel	Thursday: event 1	16-bit	Holding Register (4x)	0035	RW	MS:2	1		
Time channel	Thursday: event 2	16-bit	Holding Register (4x)	0036	RW	MS:2	1		
Time channel	Thursday: event 3	16-bit	Holding Register (4x)	0037	RW	MS:2	1		
Time channel	Thursday: event 4	16-bit	Holding Register (4x)	0038	RW	MS:2	1		
Time channel	Thursday: event 1 time of day	16-bit	Holding Register (4x)	0087	RW	MS:2	100		
Time channel	Thursday: event 2 time of day	16-bit	Holding Register (4x)	0088	RW	MS:2	100		
Time channel	Thursday: event 3 time of day	16-bit	Holding Register (4x)	0089	RW	MS:2	100		
Time channel	Thursday: event 4 time of day	16-bit	Holding Register (4x)	0090	RW	MS:2	100		
Time channel	Friday: event 1	16-bit	Holding Register (4x)	0043	RW	MS:2	1		
Time channel	Friday: event 2	16-bit	Holding Register (4x)	0044	RW	MS:2	1		
Time channel	Friday: event 3	16-bit	Holding Register (4x)	0045	RW	MS:2	1		
Time channel	Friday: event 4	16-bit	Holding Register (4x)	0046	RW	MS:2	1		
Time channel	Friday: event 1 time of day	16-bit	Holding Register (4x)	0095	RW	MS:2	100		
Time channel	Friday: event 2 time of day	16-bit	Holding Register (4x)	0096	RW	MS:2	100		
Time channel	Friday: event 3 time of day	16-bit	Holding Register (4x)	0097	RW	MS:2	100		
Time channel	Friday: event 4 time of day	16-bit	Holding Register (4x)	0098	RW	MS:2	100		
Time channel	Saturday: event 1	16-bit	Holding Register (4x)	0051	RW	MS:2	1		
Time channel	Saturday: event 2	16-bit	Holding Register (4x)	0052	RW	MS:2	1		
Time channel	Saturday: event 3	16-bit	Holding Register (4x)	0053	RW	MS:2	1		

Time channel	Saturday: event 4	16-bit	Holding Register (4x)	0054	RW	MS:2	1		
Time channel	Saturday: event 1 time of day	16-bit	Holding Register (4x)	0103	RW	MS:2	100		
Time channel	Saturday: event 2 time of day	16-bit	Holding Register (4x)	0104	RW	MS:2	100		
Time channel	Saturday: event 3 time of day	16-bit	Holding Register (4x)	0105	RW	MS:2	100		
Time channel	Saturday: event 4 time of day	16-bit	Holding Register (4x)	0106	RW	MS:2	100		
Time channel	Sunday: event 1	16-bit	Holding Register (4x)	0059	RW	MS:2	1		
Time channel	Sunday: event 2	16-bit	Holding Register (4x)	0060	RW	MS:2	1		
Time channel	Sunday: event 3	16-bit	Holding Register (4x)	0061	RW	MS:2	1		
Time channel	Sunday: event 4	16-bit	Holding Register (4x)	0062	RW	MS:2	1		
Time channel	Sunday: event 1 time of day	16-bit	Holding Register (4x)	0111	RW	MS:2	100		
Time channel	Sunday: event 2 time of day	16-bit	Holding Register (4x)	0112	RW	MS:2	100		
Time channel	Sunday: event 3 time of day	16-bit	Holding Register (4x)	0113	RW	MS:2	100		
Time channel	Sunday: event 4 time of day	16-bit	Holding Register (4x)	0114	RW	MS:2	100		



Systemair Sverige AB
Industrivägen 3
SE-739 30 Skinnskatteberg, Sweden

Phone +46 222 440 00

Fax +46 222 440 99

www.systemair.com