## Capacity correction factors Height difference and pipe length

## SYSPLIT CASSETTE 12-60 LNS HP



Capacity (Btu/h)	12K		Pipe Length (m)						
	Cooling		5	10	20	25			
	Indoor Upper	10		0.973	0.948	0.936			
11.1.1.1.1100	than Outdoor	5	0.995	0.983	0.958	0.945			
Height difference H (m)		0	1.000	0.988	0.963	0.950			
11 (11)	Outdoor Upper	-5	1.000	0.988	0.963	0.950			
	than Indoor	-10		0.988	0.963	0.950			
	Heating		5	10	20	25			
	Indoor Upper	10		0.993	0.978	0.970			
Height	than Outdoor	5	1.000	0.993	0.978	0.970			
difference H (m)		0	1.000	0.993	0.978	0.970			
	Outdoor Upper	-5	0.992	0.985	0.970	0.962			
	than Indoor	-10		0.977	0.962	0.955			

Capacity (Btu/h)	18K			Pipe Length (m)						
	Cooling		5	10	20	30				
		20			0.928	0.912				
	Indoor Upper than Outdoor	10		0.969	0.937	0.921				
		5	0.995	0.979	0.946	0.930				
Height difference H (m)		0	1.000	0.984	0.951	0.935				
		-5	1.000	0.984	0.951	0.935				
	Outdoor Upper than Indoor	-10		0.984	0.951	0.935				
	than indoor	-20			0.951	0.935				
	Heating		5	10	20	30				
		20			0.982	0.976				
	Indoor Upper than Outdoor	10		0.994	0.982	0.976				
11.1.1.1.1.1.1.1.1.1.1.1.1.1.1.1.1.1.1.1		5	1.000	0.994	0.982	0.976				
Height difference H (m)		0	1.000	0.994	0.982	0.976				
	Outdoor Upper ' than Indoor	-5	0.992	0.986	0.974	0.968				
		-10		0.978	0.966	0.960				
		-20			0.959	0.953				



Capacity (Btu/h)	24K	Pipe Length (m)								
	Cooling	5	10	20	30	40	50			
		25			$\langle$	0.914	0.894	0.874		
	Indoor Upper	20			0.944	0.924	0.903	0.883		
	than Outdoor	10		0.975	0.954	0.933	0.912	0.891		
Height		5	0.995	0.984	0.963	0.942	0.921	0.900		
difference		0	1.000	0.989	0.968	0.947	0.926	0.905		
H (m)	Outdoor Upper than Indoor	-5	1.000	0.989	0.968	0.947	0.926	0.905		
		-10		0.989	0.968	0.947	0.926	0.905		
		-20			0.968	0.947	0.926	0.905		
		-25				0.947	0.926	0.905		
	Heating		5	10	20	30	40	50		
		25			$\langle$	0.983	0.977	0.970		
	Indoor Upper than Outdoor	20			0.990	0.983	0.977	0.970		
		10		0.997	0.990	0.983	0.977	0.970		
Height		5	1.000	0.997	0.990	0.983	0.977	0.970		
difference		0	1.000	0.997	0.990	0.983	0.977	0.970		
H (m)	Outdoor Upper than Indoor	-5	0.992	0.989	0.982	0.975	0.969	0.962		
		-10		0.981	0.974	0.968	0.961	0.955		
		-20	$\sim$		0.966	0.960	0.953	0.947		
		-25				0.952	0.946	0.939		

Capacity (Btu/h)	36k		Pipe Length (m)						
Cooling			5	15	25	35	50	65	75
	Indoor Upper	30				0.885	0.845	0.805	0.778
		20			0.921	0.894	0.854	0.813	0.786
	than Outdoor	10		0.958	0.931	0.903	0.862	0.822	0.794
Height		5	0.995	0.967	0.940	0.912	0.871	0.830	0.802
differ- ence		0	1.000	0.972	0.945	0.917	0.876	0.834	0.806
H (m)		-5	1.000	0.972	0.945	0.917	0.876	0.834	0.806
	Outdoor Upper than Indoor	-10		0.972	0.945	0.917	0.876	0.834	0.806
		-20			0.945	0.917	0.876	0.834	0.806
		-30				0.917	0.876	0.834	0.806
	Heating		5	15	25	35	50	65	75
		30				0.962	0.943	0.924	0.911
	Indoor Upper	20			0.975	0.962	0.943	0.924	0.911
	than Outdoor	10		0.987	0.975	0.962	0.943	0.924	0.911
Height		5	1.000	0.987	0.975	0.962	0.943	0.924	0.911
differ- ence		0	1.000	0.987	0.975	0.962	0.943	0.924	0.911
H (m)	Outdoor Upper than Indoor	-5	0.992	0.979	0.967	0.954	0.935	0.917	0.904
		-10		0.972	0.959	0.947	0.928	0.909	0.896
		-20		$\nearrow$	0.951	0.939	0.921	0.902	0.889
		-30	$\nearrow$	$\nearrow$	$\nearrow$	0.932	0.913	0.895	0.882



Capacity (Btu/h)	48k		Pipe Length (m)							
Cooling			5	15	25	35	50	65	75	
	Indoor Upper	30		$\sim$		0.880	0.838	0.796	0.768	
		20			0.918	0.889	0.846	0.804	0.775	
	than Outdoor	10		0.956	0.927	0.898	0.855	0.812	0.783	
Height		5	0.995	0.966	0.937	0.907	0.864	0.820	0.791	
differ- ence		0	1.000	0.971	0.941	0.912	0.868	0.824	0.795	
H (m)		-5	1.000	0.971	0.941	0.912	0.868	0.824	0.795	
	Outdoor Upper than Indoor	-10		0.971	0.941	0.912	0.868	0.824	0.795	
		-20		$\sim$	0.941	0.912	0.868	0.824	0.795	
		-30		$\geq$	$\sim$	0.912	0.868	0.824	0.795	
	Heating		5	15	25	35	50	65	75	
		30		$\sim$		0.956	0.933	0.911	0.896	
	Indoor Upper	20		$\geq$	0.970	0.956	0.933	0.911	0.896	
	than Outdoor	10		0.985	0.970	0.956	0.933	0.911	0.896	
Height		5	1.000	0.985	0.970	0.956	0.933	0.911	0.896	
differ- ence H (m)		0	1.000	0.985	0.970	0.956	0.933	0.911	0.896	
	Outdoor Upper than Indoor	-5	0.992	0.977	0.963	0.948	0.926	0.904	0.889	
		-10	$\sim$	0.969	0.955	0.940	0.918	0.896	0.882	
		-20			0.947	0.933	0.911	0.889	0.875	
		-30				0.925	0.904	0.882	0.868	

Capacity (Btu/h)	60k	Pipe Length (m)							
Cooling			5	15	25	35	50	65	75
		30		$\langle$	$\langle$	0.866	0.816	0.767	0.734
	Indoor Upper	20			0.908	0.875	0.825	0.774	0.741
	than Outdoor	10		0.951	0.917	0.884	0.833	0.782	0.749
Height		5	0.995	0.961	0.927	0.893	0.841	0.790	0.756
differ- ence		0	1.000	0.966	0.931	0.897	0.846	0.794	0.760
H (m)		-5	1.000	0.966	0.931	0.897	0.846	0.794	0.760
	Outdoor Upper than Indoor	-10		0.966	0.931	0.897	0.846	0.794	0.760
		-20			0.931	0.897	0.846	0.794	0.760
		-30	$\nearrow$	$\nearrow$	$\langle$	0.897	0.846	0.794	0.760
	Heating		5	15	25	35	50	65	75
		30				0.953	0.929	0.905	0.889
	Indoor Upper	20			0.968	0.953	0.929	0.905	0.889
	than Outdoor	10		0.984	0.968	0.953	0.929	0.905	0.889
Height		5	1.000	0.984	0.968	0.953	0.929	0.905	0.889
differ- ence		0	1.000	0.984	0.968	0.953	0.929	0.905	0.889
H (m)	Outdoor Upper than Indoor	-5	0.992	0.976	0.961	0.945	0.921	0.898	0.882
		-10		0.968	0.953	0.937	0.914	0.891	0.875
		-20			0.945	0.930	0.907	0.883	0.868
		-30	$\sim$	$\nearrow$	$\nearrow$	0.922	0.899	0.876	0.861

