

## Capacity correction factors Height difference and pipe length

## **SYSPLIT DUCT 12-60 LNS HP**



Capacity (Btu/h)	12K		Pipe Length (m)						
	Cooling		5	10	20	25			
	Indoor Upper	10		0.973	0.948	0.936			
11-1-1-1-1-1-1-1-1-1-1-1-1-1-1-1-1-1-1-1	than Outdoor	5	0.995	0.983	0.958	0.945			
Height difference : H (m)		0	1.000	0.988	0.963	0.950			
11 (11)	Outdoor Upper	-5	1.000	0.988	0.963	0.950			
	than Indoor	-10		0.988	0.963	0.950			
	Heating			10	20	25			
	Indoor Upper	10		0.993	0.978	0.970			
Height	than Outdoor	5	1.000	0.993	0.978	0.970			
difference		0	1.000	0.993	0.978	0.970			
H (m)	Outdoor Upper	-5	0.992	0.985	0.970	0.962			
	than Indoor	-10		0.977	0.962	0.955			

Capacity (Btu/h)	18K		Pipe Length (m)						
Cooling			5	10	20	30			
		20			0.928	0.912			
	Indoor Upper than Outdoor	10		0.969	0.937	0.921			
	than Outdoor	5	0.995	0.979	0.946	0.930			
Height difference H (m)		0	1.000	0.984	0.951	0.935			
	Outdoor Upper than Indoor	-5	1.000	0.984	0.951	0.935			
		-10		0.984	0.951	0.935			
	triair iridooi	-20			0.951	0.935			
	Heating		5	10	20	30			
	la da sa Ulasas	20			0.982	0.976			
	Indoor Upper than Outdoor	10		0.994	0.982	0.976			
11.5		5	1.000	0.994	0.982	0.976			
Height difference : H (m)		0	1.000	0.994	0.982	0.976			
11 (11)	Outdoor Upper than Indoor	-5	0.992	0.986	0.974	0.968			
		-10		0.978	0.966	0.960			
	Cidii iidooi	-20			0.959	0.953			



Capacity (Btu/h)	24K	Pipe Length (m)							
Cooling			5	10	20	30	40	50	
		25				0.914	0.894	0.874	
	Indoor Upper	20			0.944	0.924	0.903	0.883	
	than Outdoor	10		0.975	0.954	0.933	0.912	0.891	
Height		5	0.995	0.984	0.963	0.942	0.921	0.900	
difference		0	1.000	0.989	0.968	0.947	0.926	0.905	
H (m)	Outdoor Upper than Indoor	-5	1.000	0.989	0.968	0.947	0.926	0.905	
		-10		0.989	0.968	0.947	0.926	0.905	
		-20			0.968	0.947	0.926	0.905	
	•	-25				0.947	0.926	0.905	
	Heating		5	10	20	30	40	50	
		25				0.983	0.977	0.970	
	Indoor Upper than Outdoor	20			0.990	0.983	0.977	0.970	
		10		0.997	0.990	0.983	0.977	0.970	
Height		5	1.000	0.997	0.990	0.983	0.977	0.970	
difference		0	1.000	0.997	0.990	0.983	0.977	0.970	
H (m)		-5	0.992	0.989	0.982	0.975	0.969	0.962	
	Outdoor Upper than Indoor	-10		0.981	0.974	0.968	0.961	0.955	
		-20			0.966	0.960	0.953	0.947	
		-25				0.952	0.946	0.939	

Capacity (Btu/h)	36k	Pipe Length (m)							
Cooling			5	15	25	35	50	65	75
	Indoor Upper	30				0.885	0.845	0.805	0.778
		20			0.921	0.894	0.854	0.813	0.786
	than Outdoor	10		0.958	0.931	0.903	0.862	0.822	0.794
Height		5	0.995	0.967	0.940	0.912	0.871	0.830	0.802
differ- ence		0	1.000	0.972	0.945	0.917	0.876	0.834	0.806
H (m)		-5	1.000	0.972	0.945	0.917	0.876	0.834	0.806
	Outdoor Upper than Indoor	-10		0.972	0.945	0.917	0.876	0.834	0.806
		-20			0.945	0.917	0.876	0.834	0.806
		-30				0.917	0.876	0.834	0.806
	Heating		5	15	25	35	50	65	75
	Indoor Upper than Outdoor	30				0.962	0.943	0.924	0.911
		20			0.975	0.962	0.943	0.924	0.911
		10		0.987	0.975	0.962	0.943	0.924	0.911
Height		5	1.000	0.987	0.975	0.962	0.943	0.924	0.911
differ- ence		0	1.000	0.987	0.975	0.962	0.943	0.924	0.911
H (m)		-5	0.992	0.979	0.967	0.954	0.935	0.917	0.904
	Outdoor Upper than Indoor	-10		0.972	0.959	0.947	0.928	0.909	0.896
		-20			0.951	0.939	0.921	0.902	0.889
		-30				0.932	0.913	0.895	0.882



Capacity (Btu/h)	48k	Pipe Length (m)							
Cooling			5	15	25	35	50	65	75
	Indoor Upper	30				0.880	0.838	0.796	0.768
		20			0.918	0.889	0.846	0.804	0.775
	than Outdoor	10		0.956	0.927	0.898	0.855	0.812	0.783
Height		5	0.995	0.966	0.937	0.907	0.864	0.820	0.791
differ- ence		0	1.000	0.971	0.941	0.912	0.868	0.824	0.795
H (m)		-5	1.000	0.971	0.941	0.912	0.868	0.824	0.795
	Outdoor Upper than Indoor	-10		0.971	0.941	0.912	0.868	0.824	0.795
		-20			0.941	0.912	0.868	0.824	0.795
		-30				0.912	0.868	0.824	0.795
	Heating		5	15	25	35	50	65	75
		30				0.956	0.933	0.911	0.896
	Indoor Upper than Outdoor	20			0.970	0.956	0.933	0.911	0.896
		10		0.985	0.970	0.956	0.933	0.911	0.896
Height		5	1.000	0.985	0.970	0.956	0.933	0.911	0.896
differ- ence H (m)		0	1.000	0.985	0.970	0.956	0.933	0.911	0.896
	Outdoor Upper than Indoor	-5	0.992	0.977	0.963	0.948	0.926	0.904	0.889
		-10		0.969	0.955	0.940	0.918	0.896	0.882
		-20			0.947	0.933	0.911	0.889	0.875
	•	-30				0.925	0.904	0.882	0.868

