



MINISTERIO
DE INDUSTRIA, ENERGÍA
Y TURISMO

MINISTRY OF INDUSTRY, ENERGY AND TOURISM
LICOF: Official Laboratory for Fire Testing
R.D. 1614/1985 on 1st of August
M.O. on 21st of May of 1991



AFITI
LICOF Centre for Fire Testing
and Research

Association for the Promotion of Research and Fire Safety Technology

Test Certificate

Nº: C8650/12-7

English Version

Applicant

GAVE ELECTRO, S.L.

C/ Alfred Nobel nº 16
Pol. Ind. Valldoriolf
08430 - La Roca del Vallès (BARCELONA)

**Building
Element**

Switch disconnecter

Manufacturer: Gave Electro, S.L.

Reference:

AB55625F3

AL55625F3

AB55225F3

AL55225F3

AB55641F3

AL55641F3

AB55241F3

AL55241F3

Test

Test protocol based on **EN 12101-3:2002** "Smoke and heat control systems. Part 3: Specifications for powered smoke and heat exhaust ventilators"

Test Date

03rd-Feb-12

**Certificate for
the reports**

Test report nr 8650/12-3 (issued by AFITI-LICOF on 22nd-Oct-2012).

Fire Resistance Classification

F300

Classification taking as reference what is stated in §6.1.3. table 2 of the standard **UNE-EN 12101-3:2002**

Arganda del Rey, 22nd of October of 2012



Document Signed Digitally

Signed: **Agustín Garzón Cabrerizo**
Technical Director
Fire Resistance Laboratory
Technical Director of LICOF

This Test Certificate nr C8650/12-7 supersedes the Test Certificate nr C8650/12-4 issued on 20th-mar-12

The results of this Certificate refer solely and exclusively to the specimens tested, and not to the product in general.

The specified reports include important aspects of the test performance and development which have made it possible to obtain the aforementioned Fire Resistance classification. This certificate should be used together with the referenced reports.

Cancellation or modification of the aforementioned reports implies cancellation or modification of this certificate.

HEAD OFFICE &
LABORATORIES

Camino del Estrechillo, 8
E-28500 Arganda del Rey - Madrid (Spain)

CENTRAL OFFICE &
LABORATORIES

C/ Río Estenilla, s/n - P.I. Sta. M^a de Benquerencia
E-45007 Toledo (Spain)

+34 902 112 942

+34 901 706 587

licof@afiti.com

www.afiti.com