

MINISTRY OF INDUSTRY, ENERGY AND TOURISM LICOF: Official Laboratory for Fire Testing R.D. 1614/1985 on 1st of August M.O. on 21st of May of 1991



Association for the Promotion of Research and Fire Safety Technology

Test Certificate

Nº: C8650/12-8

English Version

Applicant

GAVE ELECTRO, S.L.

C/ Alfred Nobel nº 16 Pol. Ind. Valldoriolf

08430 - La Roca del Vallès (BARCELONA)

Building **Element** Switch disconnector

Manufacturer: Gave Electro, S.L.

AB22541F4	AL55241F4
AB55221F4	AL55221F4
AB55641F4	AL55641F4
AB55621F4	AL55621F4
AB55661F4	AL55661F4
AB55261F4	AL55261F4

Test

Test protocol based on EN 12101-3:2002 "Smoke and heat control systems. Part 3:

Specifications for powered smoke and heat exhaust ventilators"

Test Date

03rd-Feb-12

Reference:

Certificate for the reports

Test report nr 8650/12-3 (issued by AFITI-LICOF on 22nd-Oct-2012).

Fire Resistance Classification

F400 (120)

Classification taking as reference what is stated in §6.1.3. table 2 of the standard UNE-EN 12101-3:2002

Arganda del Rey, 22nd of October of 2012

Signed:

Agustín Garzón Cabrerizo

Document Signed Digitally

Technical Director

Fire Resistance Laboratory Technical Director of LICOF

This Test Certificate nr C8650/12-8 supersedes the Test Certificate nr C8650/12-5 issued on 20™-mar-12

The results of this Certificate refer solely and exclusively to the specimens tested, and not to the product in general.

The specified reports include important aspects of the test performance and development which have made it possible to obtain the aforementioned Fire Resistance classification. This certificate should be used together with the referenced reports.

Cancellation or modification of the aforementioned reports implies cancellation or modification of this certificate.

HEAD OFFICE & LABORATORIES

Camino del Estrechillo, 8 E-28500 Arganda del Rey - Madrid (Spain)

***** +34 902 112 942

₼ +34 901 706 587 @ licof@afiti.com

C/ Río Estenilla, s/n - P.I. Sta. Mª de Benquerencia

www.afiti.com